

Environment and Social Management Plan (ESMP)

Document stage: Final
Project number: (P171683)

May 2021

Uzbekistan: Electricity Sector Transformation and Resilient Transmission (P171683) - Substation "Koltsevaya"

Prepared by the Joint-Stock Company «National Electric Grid of the Republic of Uzbekistan» for the World Bank (WB).

This Environmental and Social Management Plan is a document of the Receiver. The views expressed herein do not necessarily represent those of WB's Board of Directors, Management, or staff, and may be preliminary.

Table of Content

1.	EXECUTIVE SUMMARY.....	6
1.1.	GENERAL PROVISIONS OF THE PROJECT.....	6
1.2.	THE WORLD BANK'S ESSS AND THEIR RELEVANCE TO THE CURRENT SUB-PROJECT.....	8
1.3.	IMPACTS, THEIR MANAGEMENT AND MITIGATION	13
1.4.	ALTERNATIVE OPTIONS FOR SUB-PROJECT SOLUTIONS.....	15
1.5.	PUBLIC CONSULTATIONS	15
1.6.	CONCLUSION.....	15
2.	PROJECT CONCEPT.....	16
2.1.	PROJECT DESCRIPTION.....	16
2.2.	SUB-PROJECT OBJECTIVES AND TASKS	17
2.3.	SUB-PROJECT LOCATION	17
2.4.	DESCRIPTION OF THE SUBSTATION "KOLTSEVAYA" AND RELATED TL.....	18
2.4.1.	<i>Main technical and construction parameters of the sub-project</i>	<i>19</i>
2.5.	SUB-PROJECT SOLUTIONS.....	20
2.5.1.	<i>Main technical specifications</i>	<i>20</i>
2.5.2.	<i>Substation master plan.....</i>	<i>21</i>
2.6.	SCOPE OF WORK	22
3.	POLICY, LEGAL AND REGULATORY FRAMEWORKS FOR ENVIRONMENTAL AND SOCIAL ASSESSMENT	24
3.1.	NATIONAL ENVIRONMENTAL AND SOCIAL LEGISLATION OF UZBEKISTAN AND PROCEDURES	24
3.2.	REQUIREMENTS FOR SOCIAL ASSESSMENT	24
3.3.	NATIONAL REQUIREMENTS FOR ENVIRONMENTAL IMPACT ASSESSMENT (EIA).....	26
3.4.	WORLD BANK POLICY REQUIREMENTS FOR ENVIRONMENTAL AND SOCIAL ASSESSMENT.....	27
3.5.	RECOMMENDED SUB-PROJECT CATEGORIZATION.....	28
3.6.	WORLD BANK ESF REQUIREMENTS	28
3.6.1.	<i>ESS1: Assessment and Management of Environmental and Social Risks and Impacts</i> <i>28</i>	
3.6.2.	<i>ESS2: Labor and Working Conditions.....</i>	<i>28</i>
3.6.3.	<i>ESS3: Resource Efficiency and Pollution Prevention and Management.....</i>	<i>29</i>
3.6.4.	<i>ESS4: Community Health and Safety.....</i>	<i>29</i>
3.6.5.	<i>ESS5: Land Acquisition, Restrictions on Land Use and Involuntary Resettlement.....</i>	<i>29</i>
3.6.6.	<i>ESS6: Biodiversity Conservation and Sustainable Management of Living Natural Resources.....</i>	<i>29</i>
3.6.7.	<i>ESS8: Cultural Heritage;.....</i>	<i>30</i>
3.6.8.	<i>ESS10: Stakeholder Engagement and Information Disclosure.....</i>	<i>30</i>
4.	ENVIRONMENTAL AND SOCIAL IMPACT ASSESSMENT AND MITIGATION MEASURES.....	31
4.1.	ENVIRONMENTAL IMPACT ASSESSMENT METHODOLOGY	31
4.2.	IMPACT SCREENING	31
4.2.1.	<i>Impacts and Mitigation Measures - Design Stage.....</i>	<i>32</i>
4.2.2.	<i>Impacts and Mitigation Measures - Construction Stage.....</i>	<i>33</i>
4.2.3.	<i>Impacts on land resources.....</i>	<i>34</i>
4.2.4.	<i>Waste generation.....</i>	<i>36</i>
4.2.5.	<i>Impacts on water resources, soil, grounds.....</i>	<i>36</i>
4.2.6.	<i>Impact on atmospheric air.....</i>	<i>37</i>
4.2.7.	<i>Noise and vibration impact.....</i>	<i>37</i>
4.2.8.	<i>Impacts on vegetation and wildlife.....</i>	<i>38</i>
4.2.9.	<i>Chance finds (historical monuments or cultural finds.....</i>	<i>39</i>
4.2.10.	<i>Health and safety of workers and community</i>	<i>40</i>
4.2.11.	<i>Traffic and Safety on construction sites</i>	<i>40</i>
4.2.12.	<i>Magnetic field impact</i>	<i>41</i>
4.2.13.	<i>Electric current impact.....</i>	<i>41</i>
4.2.14.	<i>Pollution of surface watercourses, groundwater, soils.....</i>	<i>41</i>
4.2.15.	<i>Impacts and Mitigation Measures - Operation Stage.....</i>	<i>42</i>
5.	Organizational Requirements.....	44
5.1.	ORGANIZATIONAL STRUCTURE AND DIVISION OF RESPONSIBILITIES.....	44
5.2.	NATIONAL ELECTRIC GRID OF UZBEKISTAN (NEGU)	44

5.3.	REPORTING REQUIREMENTS	45
6.	ENVIRONMENTAL AND SOCIAL IMPACT MITIGATION PLAN	47
7.	ENVIRONMENTAL AND SOCIAL MONITORING PLAN	66
7.1.	ESTIMATES FOR PROPOSED ENVIRONMENTAL PROTECTION MEASURES	66
8.	PUBLIC CONSULTATIONS AND INFORMATION DISCLOSURE	79
8.1.	GENERAL INFORMATION	79
8.2.	PRINCIPLES OF CONSULTATION	79
8.3.	STAKEHOLDER ENGAGEMENT ACTIVITIES	79
8.4.	STAKEHOLDER ENGAGEMENT	80
8.5.	GRIEVANCE MECHANISM (GM)	80
ANNEXES	83
ANNEX 1. MINUTES OF THE PUBLIC CONSULTATION	83
ANNEX 2. PROPOSED FORMS FOR MONITORING IMPLEMENTATION	93
ANNEX 3. ASBESTOS CONTAINING MATERIAL MANAGEMENT PLAN (EXAMPLE)	94

List of Tables

TABLE 1. ENVIRONMENTAL CONDITIONS OF THE SUB-PROJECT AREA	18
TABLE 2: MAIN TECHNICAL SPECIFICATIONS OF THE 500 KV SUBSTATION	20
TABLE 3 MAIN TECHNICAL PARAMETERS OF THE SUB-PROJECT	21
TABLE 4. LIST OF ENVIRONMENTAL LAWS RELEVANT TO THE PROJECT	24
TABLE 5. LIST OF SOCIAL PROPERTY AND LAND OWNERSHIP LAWS RELEVANT TO THE PROJECT	25
TABLE 6. PRELIMINARY DATA ON LAND ACQUISITION AND NUMBER OF AFFECTED FARMERS IN TASHKENT REGION	35
TABLE 7. PRELIMINARY DATA ON LAND ACQUISITION AND QUANTITY OF AFFECTED FARMERS IN SYRDARYA REGION	35
TABLE 8. SUMMARY TABLE OF IMPACTS	43
TABLE 9. ENVIRONMENTAL AND SOCIAL MANAGEMENT PLAN	48
TABLE 10: COSTS OF ENVIRONMENTAL PROTECTION FOR MITIGATION AND MONITORING	67
TABLE 11. ENVIRONMENTAL AND SOCIAL MONITORING PLAN	69
TABLE 12. GRIEVANCE REDRESSES MECHANISM AND ITS LEVELS	81

List of Figures

FIGURE 1.LOCATION OF SUBSTATION	8
FIGURE 2. FARMS - KOLTSEVAYA SUBSTATION AND TRANSMISSION LINES LAND VIEW	17
FIGURE 3: SUBSTATION "KOLTSEVAYA" 500 TASHKENT REGION	18
FIGURE 4. ACCESS ROAD TO THE CONSTRUCTION SITE OF THE KOLTSEVAYA SUBSTATION	19
FIGURE 5: ORGANIZATIONAL STRUCTURE OF THE ENVIRONMENTAL PROTECTION AUTHORITY	44

Abbreviations

JSC	Joint-stock company
ACM	Asbestos-Containing Materials
AT	Autotransformers
BOD	Biological oxygen demand
BOQ	Bill of quantities
CM	Cabinet of Ministers
DEIS	Draft Environmental Impact Statement
EA	Environmental assessment
EIA	Environmental Impact Assessment
EMF	Electromagnetic field
EMoP	Environmental Monitoring Plan
EMP	Environmental Management Plan
ESMP	Environmental and Social Management Plan
ESS	Environmental and Social Standards
GHG	Green-house gases
GIIP	Global International Industry Practice
GosSIK	State Specialized Inspection of Analytical Control
GOST	State Technical Design Standard
GoU	Government of Uzbekistan
GM	Grievance Mechanism
HR	High risk
IFC	International Finance Corporation
IP	Indigenous Peoples
LR	Low risk
MPC	Maximum permissible concentrations
MPD	Maximum permissible discharges
MPL	Maximum permissible levels
MR	Moderate risk
MSW	Municipal solid waste
NEGU	Joint-Stock Company “National Electric Grid of Uzbekistan”
NGO	Non-governmental organization
O&M	Operations and maintenance
OL	Overhead lines
OHTL	Overhead Power Transmission Line
PIU	Project Implementation Unit
PP	Decree of the President of Uzbekistan
PPE	Personal Protective Equipment
PVC	Polyvinyl chloride
RCM	Resolution of the Cabinet of Ministries
RE	Renewable energy
RPIU	Regional project Implementation Unit
Ruz	Republic of Uzbekistan
SanPiN RUz	Sanitary rules and regulations of the Republic of Uzbekistan
SASMR	Semi-annual social monitoring reports
SCB	Substation control building
SCEEP	State Committee on Ecology and Environmental Protection (or Goskomekologiya)
SEA/SH	Sexual exploitation and abuse, or sexual harassment
SEAP	Site Environmental Action Plan
SES	Sanitary Epidemiological Service
SNR	Sanitarian Norms and Rules

SR	Substantial risk
TPP	Thermal power plant
USD (US\$)	United States dollar
TL	Transitions Lines
UZS	Uzbek Sum
WB	World Bank
ZRU	Law of the Republic of Uzbekistan

1. Executive summary

1.1. General provisions of the Project

The implementation of the "**Electricity Sector Transformation and Resilient Transmission**" Project aims to improve the reliability of the transmission system and the operation of the newly established transmission company to facilitate the development of the electricity market in Uzbekistan. The project is implemented by NEGU (National Electric Grid of Uzbekistan) under the Ministry of Energy of Uzbekistan and funded by the World Bank (WB). The proposed project will have four components. The Environmental and Social Management Plan is being developed under the Component 2 - **Power grid strengthening and renewable energy integration**.

This component will finance a portion of the NEGU priority investment program for 2021–2026, including upgrade and modernization of existing high-voltage substations and construction of a new transmission substation and related to it lines. This component will accordingly support: (a) modernization of 22 priority substations that were identified for rehabilitation across the country; (b) construction of new substation: 500/220 kV "Koltsevaya" to release overloading on neighboring substations and to meet growing demand in the respective regions; (c) construction of related 500 kV and 220 kV transmission lines to connect the aforementioned substation to the national transmission network.

Project location. The project will be implemented in 10 regions of the Republic of Uzbekistan, (Andijan, Fergana, Tashkent, Syrdarya, Samarkand, Bukhara, Navoi, Kashkadarya, Surkhandarya, Khorezm) and in Tashkent city.

Sub-project location. Construction of the Substation "Koltsevay" 500 kV and related 500 kV and 220 kV transmission lines will be carried out in Tashkent and Syrdarya region. The substation itself will be constructed in Kuyi-Chirchik district, 56 km from Tashkent city.

SS Kolcevaya to be located in the Central part of the Uzbek Network. Share of electric power consumption in the Central part of the power network is about 32 % of total consumption of the country. Development of industry, private sector and improvement of living conditions and welfare of the population in Tashkent city and Tashkent region causes intensive growth of power consumption. At the same time, the construction of new power plants and their commissioning (Novo-Syrdarya TPP with installed capacity of 3000, the year of commissioning 2023) requires ensuring high reliability and capacity of transmission networks and their stable operation.

The 500 kV Koltsevaya substation will have the technical capability to transfer up to 1602 MVA of capacity. Annual power transmission to consumers will be up to 4.5 billion kWh, depending on the operation regime of consumers and power plants.

Subproject solutions will include:

- Construction of 500/220/10 kV "Koltsevaya" substation with two groups of autotransformers with capacity of 801 MVA (2*3*267 MVA), with one phase backup autotransformer and one group of three-phase shunt reactors, installation of 18 cells at outdoor switchgear-220 kV Koltsevaya substation.
- Construction of separate two new 220 kV overhead transmission lines between the designed "Koltsevaya" substation and "Feruz" substation. At the same time, a part of the existing "L-Feruz-1, 2" lines of about 68 km in length from the "Feruz" substation to the "Ozodlik" substation, including those passing through the territory of the Republic of Kazakhstan, is being dismantled.

- Construction of 2 double-circuit 220 kV overhead transmission lines to "Keles" substation and "Ozodlik" substation and one double-circuit 220 kV overhead transmission line.

Potential socio-economic impact. Direct and indirect benefits are expected from this sub-project. The socio-economic impact of the sub-project will be mainly positive and related to the improvement of the district and Tashkent region's electricity transmission network as a whole. Stable electricity supply will improve living conditions, incomes and economic conditions for business activities.

Problems with electricity supply in households negatively affect the quality of life of all family members, especially women and children. Unstable electricity supply affects women's use of their time in traditional social roles, and creates barriers for working women. Since women usually have most of the household and family responsibilities, they are the main consumers of electricity in the households. Women cannot use household appliances, such as washing machines or electric cookers due to the current deficient power supply. Direct benefits also include the purchase of modern equipment to upgrade and automate the substation. Indirect benefits include increased knowledge of substation staff and enhanced capacity of the NEGU as a whole.

Potential environmental impact. The sub-project activities will support a wide range of investments focused on the need to modernize and automate the substation, build a new substation and transmission lines and will not only have a positive social and economic impact, but also an environmental impact.

Construction of new "Koltsevaya" substation and new transmission lines cause medium, but reversible environmental impacts during their implementation, resulting in both positive and negative consequences.

During the construction works on substation's buildings and infrastructure, as well as, new transmission lines, a number of different adverse environmental and social impacts can occur, such as (a) increased environmental pollution from waste; (b) noise; (c) air pollution from dust, combustion residues; d) increased pollution of groundwater and surface water resulting from inadequate prevention and mitigation measures; (e) degradation and soil contamination; (f) threats to human health resulting from improper handling of heavy equipment during construction activities; (g) temporary restrictions on access to private and public assets (land, commercial facilities, roads, markets, trees etc.) (h) land acquisition necessitated by construction activities. These impacts are typical of construction activities and can be mitigated by the application of best construction practices and/or appropriate mitigation measures.

Issues of involuntary resettlement. The sub-project will use the land of nearby farms. For the construction of the substation, a permanent acquisition of 30 hectares of land is required. The construction of power transmission lines requires permanent and temporary acquisition of farmland in the Tashkent and Syrdarya regions. In total, about 120 farms are affected in the two regions, but no involuntary physical resettlement of households is expected. The land acquisition process has been initiated and a Social Audit is being conducted to ascertain the process and compensation is compliant with requirements under World Bank Environmental and Social Standard no. 5 on Land Acquisition, Restrictions on Land Use and Involuntary Resettlement

Sub-project category. According to the World Bank standard on the impact of social and environmental risks ESS 1, the 500 kV "Koltsevaya" substation and related TL construction sub-project is categorized as **Substantial** (SR), since social impacts are permanent and irreversible (land acquisition), therefore the development of the ESMP should focus on

specific environmental/social issues.

Given the location of the substation at a distance of 1000 meters from residential buildings and the absence of infrastructure (roads, markets, etc.) near the substation, only farmer's land is around.




Figure 1. Location of substation

1.2. The World Bank's ESSs and their relevance to the current sub-project

The following World Bank Standards have been applied in this report, based on the environmental and social assessment of the field studies and the information provided by the sub-project organization.

Environmental and Social Standards (ESSs)	Presence in the sub-project	Clarifications and basic requirements
<p>ESS1: Assessment and Management of Environmental and Social Risks and Impact ESS1 sets out the Client's responsibilities for assessing, managing, and monitoring environmental and social risks and impacts associated with each stage of a project supported by the Bank through Investment Project Financing, in order to achieve environmental and social outcomes consistent with the Environmental and Social Standards (ESSs). As required by this standard, the ESIA shall be conducted on the basis of current information, including an accurate description and delineation of the project</p>	<p>Yes</p>	<p>Overall, the sub-project will have a number of positive social and environmental impacts. It supports technical assistance and energy capacity building activities, increases transformer capacity; increases the reliability of electricity supply to consumers throughout the Republic's energy system, ensuring a safe, reliable and affordable electricity supply for households. However, activities during the construction period of substation and related TL may result in adverse impacts and therefore the sub-project will need to introduce substantial environmental and social pre-screening, mitigation and monitoring systems. Sub-project activities can cause a number of direct environmental risks</p>

Environmental and Social Standards (ESSs)	Presence in the sub-project	Clarifications and basic requirements
<p>and any associated aspects, and environmental and social baseline data at an appropriate level of detail sufficient to inform characterization and identification of risks and impacts and mitigation measures. The assessment will identify the project's potential environmental and social risks and impacts, paying particular attention to those that may disproportionately affect disadvantaged and/or vulnerable social groups; examine project alternatives; identify ways of improving project selection, siting, planning, design, and implementation in order to apply the mitigation hierarchy for adverse environmental and social impacts and seek opportunities to enhance the positive impacts of the project.</p>		<p>such as: increased environmental pollution with waste, noise, dust, air pollution, health hazards and labor safety issues due to civil works. They can be mitigated easily by applying good construction practices and following the provisions of the Environmental and Social Management Plans.</p>
<p>ESS2: Labor and Working Conditions.</p> <p>ESS2 recognizes the importance of employment creation and income generation in the pursuit of poverty reduction and inclusive economic growth. Receivers can promote sound worker-management relationships and enhance the development benefits of a project by treating workers in the project fairly and providing safe and healthy working conditions. ESS2 applies to project workers including full-time, part-time, temporary, seasonal and migrant workers.</p>	<p>Yes</p>	<p>The sub-project includes direct workers (employees of NEGU) as well as contracted workers (employees of contractors). NEGU and sub-project beneficiaries conducted screening for primary suppliers to ensure that they have no history of forced and child labor or other significant labor, environmental and social violations. No forced or unpaid labor will be used in any sub-project activities or in any activities that may be related or associated with the sub-project (e.g. public infrastructure constructed in support of sub-project investments). NEGU is responsible for raising awareness on these provisions among relevant stakeholders (e.g., local khokimiyats and communities) and monitoring compliance through the implementation of the ESMP activities.</p>
<p>ESS3: Resource Efficiency and Pollution Prevention and Management</p> <p>ESS3 recognizes that economic activity and urbanization often generate pollution to air, water, and land, and consume finite</p>	<p>Yes</p>	<p>Sub-project works associated with civil works risks and impacts and proposed mitigation measures related to relevant requirements of ESS3, including raw materials, equipment, water use, air pollution, hazardous materials, and hazardous waste will be included in the</p>

Environmental and Social Standards (ESSs)	Presence in the sub-project	Clarifications and basic requirements
<p>resources that may threaten people, ecosystem services, and the environment at the local, regional, and global levels. The current and projected atmospheric concentration of green-house gases (GHG) threatens the welfare of current and future generations. At the same time, more efficient and effective resource use, pollution prevention, and GHG emission avoidance, and mitigation technologies and practices have become more accessible and achievable. This ESS sets out the requirements to address resource efficiency and pollution prevention and management throughout the project life cycle consistent with Global International Industry Practice (GIIP).</p>		<p>ESMP.</p>
<p>ESS4: Community Health and Safety ESS4 recognizes that activities, equipment, and infrastructure can increase community exposure to risks and impacts. In addition, communities that are already subjected to impacts from climate change may also experience an acceleration or intensification of impacts due to project activities. ESS4 addresses the health, safety, and security risks and impacts on project-affected communities and the corresponding responsibility of Receivers to avoid or minimize such risks and impacts, with particular attention to people who, because of their particular circumstances, may be vulnerable.</p>	<p>Yes</p>	<p>The ESMP for the substation and TL construction will include the necessary measures to ensure effective waste management and handling of hazardous materials, as well as training requirements in this regard; work-related health risk assessment; works and traffic safety; excessive noise and dust levels, site safety awareness and access restrictions; and labor influx. All contractors developed and adhered to Codes of Conduct, including requirements for respectful behavior and interaction with local communities and within work sites, prohibition from engaging in illicit activities, sexual exploitation and abuse, or sexual harassment (SEA/SH), forced or child labor.</p>
<p>ESS5: Land Acquisition, Restrictions on Land Use and Involuntary Resettlement ESS5 recognizes that projects-related land acquisition and</p>	<p>Yes</p>	<p>The sub-project will use the land of nearby farms. For the construction of the substation, a permanent acquisition of 30 hectares of land is required. The construction of power transmission lines</p>

Environmental and Social Standards (ESSs)	Presence in the sub-project	Clarifications and basic requirements
<p>restrictions on land use can have adverse impacts on communities and persons. Project-related land acquisition or restrictions on land use may cause physical displacement (relocation, loss of residential land, or loss of shelter), economic displacement (loss of land, assets, or access to assets leading to loss of income sources or other means of livelihood), or both. The term “involuntary resettlement” refers to these impacts.</p>		<p>requires permanent and temporary acquisition of farmland in the Tashkent and Syrdarya regions. In total, about 120 farms are affected in the two regions, and no involuntary physical resettlement of households is expected. A Social Audit is being conducted for the areas where acquisition has been initiated, and if any additional lands will be required, a Resettlement Action Plan will be prepared on the basis of Resettlement Framework of the sub-project</p>
<p>ESS6: Biodiversity Conservation and Sustainable Management of Living Natural Resources. ESS6 recognizes that protecting and conserving biodiversity and sustainably managing living natural resources are fundamental to sustainable development. Impacts on biodiversity can therefore often adversely affect the delivery of ecosystem services. This standard aims to protect natural habitats and their biodiversity; avoid significant conversion or degradation of critical natural habitats; and ensure the sustainability of the services and products that natural habitats provide to human society.</p>	<p>Yes</p>	<p>The sub-project activities within the substation and transmission lines will take place on agricultural land and are expected to result in minimal impacts on biodiversity. Consequently, the standard for this sub-component of the sub-project is relevant. Sub-project activities related to risks and impacts on biodiversity and proposed mitigation measures associated with the relevant requirements of ESS 6 will be included in the ESMP.</p>
<p>ESS7: Indigenous Peoples/Sub-Saharan African Historically Underserved Traditional Local Communities IP – distinct, vulnerable, social and cultural group attached to geographically distinct habitats or historical territories, with separate culture than the project area, and usually different language. The Standard aims to foster full respect for human rights, economies, and cultures</p>	<p>No</p>	<p>The Republic of Uzbekistan does not have such groups of people/communities and thus this ESS is not relevant for the Sub-project.</p>

Environmental and Social Standards (ESSs)	Presence in the sub-project	Clarifications and basic requirements
of IP, and to avoid adverse effects on IP during the project development.		
<p>ESS8: Cultural Heritage ESS8 recognizes that cultural heritage provides continuity in tangible and intangible forms between the past, present and future. It sets out measures designed to protect cultural heritage throughout the project life cycle.</p>	Yes	It is expected that Sub-project activities may have a minor impact on any physical cultural resources (cemeteries, solitary graves, previously unrecorded cultural heritage monuments at district level), during construction activities associated mainly with power lines. Sub-project activities associated with risks and impacts on cultural heritage and proposed mitigation measures associated with the relevant requirements of ESS 8 will be included in the ESMP in the form of Chance Find Procedures.
<p>ESS9: Financial Intermediaries (FIs) ESS9 recognizes that strong domestic capital and financial markets and access to finance are important for economic development, growth and poverty reduction. Financial organizations are required to monitor and manage the environmental and social risks and impacts of their portfolio and FI subprojects, and monitor portfolio risk, as appropriate to the nature of intermediated financing.</p>	No	No financial intermediaries.
<p>ESS10: Stakeholder Engagement and Information Disclosure This ESS recognizes the importance of open and transparent engagement between the NEGU and project stakeholders as an essential element of good international practice . Effective stakeholder engagement can improve the environmental and social sustainability of projects,</p>	Yes	A Stakeholder Engagement Plan has been prepared, disclosed and consulted for the whole sub-project, while the draft ESMP for the subproject will be disclosed and discussed in the region before the final assessment takes place. Continued stakeholder consultations will be conducted during sub-project implementation.

<i>Environmental and Social Standards (ESSs)</i>	<i>Presence in the sub-project</i>	<i>Clarifications and basic requirements</i>
enhance project acceptance, and make a significant contribution to successful project design and implementation.		

1.3. Impacts, their management and mitigation

Land acquisition – The sub-project activities involve involuntary land acquisition for the construction of the substation and transmission lines, all sub-project activities will be carried out on the land allocated (temporary and permanent allocation) only after all compensation and allocation of land to replace the land has taken place.

Construction site – The construction site will be organized on the farmland (30 hectares) allocated for the construction of the substation, where agricultural activities previously were carried out. The construction site will contain workers' trailers, temporary bio-toilets, warehouses, and a specially equipped fueling area for the equipment by a fuel truck. The construction workers will be accommodated in a nearby village.

Air Pollution - Dust will form around the construction area and transportation route. Earthworks, a temporary work area, a bypass road, a soil dump as well as the operation of construction equipment will be sources of dust and combustion products of diesel fuel (nitrogen oxides, sulphur oxides, nitrogen oxides, carbon, soot, aldehydes, benzo(a)pyrene).

Noise and vibration - Construction machinery, transport trucks will be a source of noise and vibration. Works will be carried out only during daytime.

Electric current impact - the objects of electric current exposure at the substation and TL can be service personnel, as well as people and animals-when the potential is removed from the earthing devices when short-circuit and lightning currents flow through them.

Water Pollution and Water Use – Earthworks, construction site work, oil storage, hazardous materials storage, as well as soil waste will become sources of water pollution. Leakage of oil, hazardous materials, construction waste and household waste can lead to chemical pollution.

Hazardous materials and soil contamination - Leakages of fuel, lubricants, construction waste and pit latrines can cause soil contamination.

Waste - Construction work will inevitably generate solid and liquid waste, including inert waste (e.g. concrete, wood, plastic, etc.) and hazardous waste (e.g. used oil). In addition, uncontrolled wastewater and "grey water" discharges (e.g. from toilets and canteens) from construction sites can also cause odours and contaminate local water resources.

Operating a construction site for workers generates household waste. Excavation work generates rock dumps and excavated soil. Other construction activities generate construction waste such as wood, metal, plastic, grass, paper and hazardous waste. Without appropriate waste management measures, local environmental pollution may occur.

Flora and fauna of the sub-project area – The construction works will be carried out on agricultural land and therefore no significant damage to vegetation, in particular to trees, is foreseen. During construction activities, as a result of noise effects, birds and animals will

migrate to a safe distance from the construction site. The population and numbers of animals and birds will not change.

There are no plants listed in the Red Book of Uzbekistan on the territory of the sub-project area, only the stork is listed from the animal world.

Public Health and Safety - The storage of fuels and chemicals creates health and safety risks that can also affect local communities. Trucks, materials transporters and other construction vehicles will use the same public road. The risk of accidents with local vehicles, pedestrians will be higher during the construction period.

Occupational health and safety - Employee rights, including occupational health and safety, must be taken into account to avoid accidents and injuries, loss of labor resources, labor abuses and to ensure fair treatment, remuneration, working and living conditions. The Labor Management Procedures for the whole sub-project sets the guidelines for the contractor's LMP.

Physical and cultural resources – The possibility of finds may arise during substation construction works, especially power transmission lines, given the masses of land and excavation works. The report provides for the use of "chance finds" procedures which include a pre-approved approach to the management and preservation of material that may be encountered during the course of the sub-project.

Road – The substation and TL construction will inevitably cause temporary inconvenience to residents because the roads will be occupied by heavy vehicles and machinery. Access to the facilities under construction is envisaged on existing roads.

During the construction phase, the contractor shall have the contractual obligation to minimize short-term environmental impacts using known traditional methods such as dust suppression on the road and construction site, setting vehicle speed limits in the sub-project area, ensuring sufficient shower and toilet facilities for construction workers, proper management of domestic waste (especially when disposing of food waste), and the introduction of health and safety standards and regulations. The appointed sub-project manager must be vigilant in ensuring compliance with contractual environmental and safety provisions.

Impacts during the operation stage

No significant environmental impacts from emissions, discharges and waste are expected during the operational phase of the substation and TL, as the facility itself is greenfield substation.

The impacts will mainly be positive. Equipping the substation with new equipment (500 kV "Koltsevaya" substation has the technical capacity to transmit up to 1,602 MVA of capacity. The transmission of electricity to consumers will be up to 4.5 billion kW-h depending on the mode of operation of consumers and power plants) will improve operation of power transmission system in the district and Tashkent region as a whole. Stable power supply will improve living conditions, income and economic conditions for entrepreneurship.

Minor impacts during the operational phase may be related to the generation of waste, electrical and magnetic radiation. Waste can be a source of contamination of soil, surface and ground water. It is therefore essential that these wastes are disposed of in a timely manner. To prevent negative effects on substation personnel from electrical and magnetic radiation, periodic measurements of the electrical and magnetic fields are recommended.

1.4. Alternative options for sub-project solutions

As a "zero option" it is considered not to implement the sub-project solution for "Koltsevaya" 500 kV and related TL construction. This excludes improvements in the reliability of electricity supply to the population of the region, developing social facilities and industrial enterprises.

The construction solutions proposed for Substation "Koltsevaya" 500 kV and related TL in the sub-project are optimal and have benefits in terms of environmental and social impact and industry development due to the measures adopted in the sub-project.

Therefore, as a result of comprehensive consideration of substation and TL construction, a technological decision has been made to: carry out works and measures to construct the Substation "Kotsevya" 500 kV and related TL in the Tashkent and Syrdarya region. The implementation of the technological solutions proposed in this sub-project will enable the uninterrupted supply of electricity to the population of the regions and Tashkent city.

1.5. Public consultations

During the preparation of the ESMP, it was disclosed on March 31st, 2021 and consulted on April 7, 2021 with stakeholders. Based on the suggestions received during the consultations, the ESMF, ESMPs, LMP, SEP and RF were updated, finalized and published on NEGU's website and will be published on the World Bank external website

An environmental summary in Uzbek language will be published prior to the final public consultation. The results of the public consultation, responses and questions, minutes, photographs and lists of participants are presented in Annex № 1 of this report.

1.6. Conclusion

The Environmental and Social Management Plan for the Substation "Koltsevaya" 500 kV and related TL was carried out based on the analysis of the social surroundings and the environmental state of the environment and taking into account the expected consequences of the implementation of the measures. The implementation of the measures provided by the sub-project will ensure uninterrupted, reliable operation of the power supply system of the Tashkent and Syrdarya regions population.

Thus, the assessment of the identified impacts of the sub-project consisting of substation and TL construction will result in improved energy supply, which will have a positive impact on electricity transmission and living standards of the population.

Consequently, it can be recommended that the sub-project is considered environmentally feasible. Implementation of the sub-project will not cause adverse environmental impacts and the relevant measures listed in the previous section will, if implemented, fully comply with international requirements and reduce/mitigate adverse impacts.

2. Project Concept

2.1. Project description

Project Objective. The "Electricity Sector Transformation and Resilient Transmission" Project's development objective is to strengthen the performance of NEGU and improve the capacity and reliability of the power transmission system to integrate large scale renewable energy sources.

The proposed project will consist of the following four components:

- (i) **Digitalization of the electricity transmission sector:**
The objectives of this component is to take advantage of modern digital technologies to support the enhanced monitoring, automation, and control of the power system in Uzbekistan.
- (ii) **Power grid strengthening and renewable energy integration:** This component will finance a portion of the NEGU priority investment program for 2021–2026, including upgrade and modernization of existing high-voltage substations and construction of a new transmission substation and related to it lines. This component will accordingly support: (a) modernization of 22 priority substations that were identified for rehabilitation across the country; (b) construction of a new substation: 500/220 kV "Koltsevaya" to release overloading on neighboring substations and to meet growing demand in the respective regions; (c) construction of related 500 kV and 220 kV transmission lines to connect the aforementioned substation to the national transmission network.
- (iii) **NEGU Institutional Development and Project Implementation Support:** This component will support developing and improving the institutional capacity and technical capabilities of NEGU to ensure it can effectively carry out its functions of reliable operation of the transmission system and electricity market in Uzbekistan.
- (iv) **Electricity Market Development:** This component will provide technical assistance for the design and implementation of the electricity sector's transition plan toward the establishment of a wholesale electricity market and will include preparation of secondary legislation, market rules, institutional capacity building as well as design and implementation of systems required for market operation and management.

This ESMP considers Component 2 **Power Grid Strengthening and renewable energy integration**, in particular the construction of new Substation "Koltsevaya" 500, located in Tashkent region and related transmission lines in Tashkent and Syrdarya regions.

Sub-project solutions will include:

- Construction of 500/220/10 kV "Koltsevaya" substation with two groups of autotransformers with capacity of 801 MVA (2*3*267 MVA), with one phase backup autotransformer and one group of three-phase shunt reactors, installation of 18 cells at outdoor switchgear-220 kV Koltsevaya substation.
- Construction of separate two new 220 kV overhead transmission lines between the designed "Koltsevaya" substation and "Feruz" substation. At the same time, a part of the existing "L-Feruz-1, 2" lines of about 68 km in length from the "Feruz" substation to the "Ozodlik" substation, including those passing through the territory of the Republic of Kazakhstan, is being dismantled.
- Construction of 2 double-circuit 220 kV overhead transmission lines to "Keles" substation and "Ozodlik" substation and one double-circuit 220 kV overhead transmission line.

2.2. Sub-project objectives and tasks

The construction of a new 500 kV "Koltsevaya" substation with 220 and 500 kV overhead transmission lines (TL) for consumers in Tashkent city and Tashkent region will increase the stability of the energy system as a whole and improve power supply conditions for industrial facilities, businesses and the population.

The 500 kV "Koltsevaya" substation has the technical capacity to transfer up to 1602 MVA of capacity.

The annual transmission of electricity to consumers will be up to 4.5 billion kWh, depending on the operational regime of consumers and power plants.

The condition for ensuring timely, efficient and high-quality implementation of the proposed Sub-project is:

- maximum use of equipment, components and materials produced in the country, in strict compliance with the specifications.

An analysis of the capabilities of domestic electrical equipment and material manufacturers has shown that they have the ability to provide the full range of products in the required volume and of adequate quality for the successful implementation of this Sub-project.

2.3. Sub-project location

The Substation "Koltsevaya" 500 will be constructed on a 30 ha plot of land in Kuiy-Chirchik district, Tashkent region, 56 km from Tashkent city. About 213 km of overhead transmission lines will be 220 kV and 72 km of lines will be 500 kV, these lines will cross the Tashkent and Syrdarya regions. The design and construction of the substation and transmission line are planned on farm land subject to permanent and temporary land acquisition.



Figure 2. Farms - Koltsevaya Substation and Transmission lines land view

Table 1. Environmental conditions of the Sub-project Area

№	Name	Unit
1.	Wind pressure	0.45 kPa
2.	Ice-coated area	II
3.	Minimum temperature	- 29,5°C
4.	Maximum temperature	- +44,5°C
5.	Seismic	8 points



Figure 3: Substation "Koltsevaya" 500 Tashkent region

2.4. Description of the Substation "Koltsevaya" and related TL

SS Kolcevaya to be located in the Central part of the Uzbek Network. Share of electric power consumption in the Central part of the power network is about 32 % of total consumption of the country. Development of industry, private sector and improvement of living conditions and welfare of the population in Tashkent city and Tashkent region causes intensive growth of power consumption. At the same time, the construction of new power plants and their commissioning (Novo-Syrdarya TPP with installed capacity of 3000, the year of commissioning 2023) requires ensuring high reliability and capacity of transmission networks and their stable operation.

The sub-project envisages the design of a new 500 kV substation. The site for the substation has been selected in accordance with the land legislation of the Republic of Uzbekistan and the legislation on nature protection and use of natural resources.

The orientation of the substation site on the ground and the placement of structures on the site are determined by the conditions of the approaches feeding the 500 kV overhead transmission line, the 220 kV overhead transmission line exits and the route of the access road.



Figure 4. Access road to the construction site of the Koltsevaya substation

2.4.1. Main technical and construction parameters of the sub-project

- Construction of 500/220/10 kV "Koltsevaya" substation with two groups of autotransformers with capacity of 801 MVA (2*3*267 MVA), with one phase standby autotransformer and one group of three-phase shunt reactors.

- Installation of 18 units of cells in outdoor switchgear-220 kV "Koltsevaya" substation according to the scheme "two working sectional switches and bypass busbar system with two bypass and two busbar couplers (scheme № 220-14), including 2 feeder cells from AT-500 kV, 2 bypass breaker, 2 reactor breakers, 2 section breakers, 10 line bays (to "Feruz" substation, "Keles" substation, "Ozodlik" substation, "Yuksak" substation and 2 reserve bays for 2 overhead lines to "Sergeli" substation).

- Construction of separate two new 220 kV overhead transmission lines between the designed "Koltsevaya" substation and "Feruz" substation. At the same time, a part of the existing "L-Feruz-1, 2" lines of about 68 km in length from the "Feruz" substation to the "Ozodlik" substation, including those passing through the territory of the Republic of Kazakhstan, is being dismantled;

- Construction of 2 double-circuit 220 kV overhead TL to "Keles" substation and "Ozodlik" substation and one double-circuit 220 kV overhead TL (for the "Incoming-Outgoing" scheme of existing 220 kV overhead TL between "Keles" substation and "Yuksak" substation), which will create electrical connections using existing sections of 220 kV "L-Keles-Feruz"-1 and 2 between the system substations.

The lengths of the 220 kV overhead lines according to the feasibility study are as follows:

- single-circuit 220 kV overhead TL "L-Feruz-1" about 43 km;
- single-circuit 220 kV overhead TL "L-Feruz-2" about 43 km;
- double-circuit 220 kV overhead TL "L-Ozodlik-1", "L-Keles-2" about 42 km;
- double-circuit 220 kV overhead TL "L-Ozodlik-2", "L-Keles-1" about 42 km;
- double-circuit 220 kV overhead TL "L-Yuksak", "L-Keles-3" about 43 km.

The lengths of 500 kV overhead transmission lines according to the feasibility study are as follows:

- 500 kV overhead TL "L-502" (Syrday TPP- "Koltsevaya" substation) is about 36 km;

- 500 kV overhead TL "L-552" ("Koltsevaya" - "Tashkent" substations) is about 36 km.

In order to reduce operating costs, increase reliability and take into account the best international experience in the development of power systems using digital technologies (digitalization), the sub-project "Construction of a new 500 kV "Koltsevaya" substation and 500-220 kV overhead transmission lines" at the "Koltsevaya" substation will use modern digital technologies (digital substation).

The construction and commissioning of the "Koltsevaya" substation will certainly improve the reliability of electricity supply to consumers in Tashkent and the Tashkent region, as it improves the reliability of main power grids and transmission substations, from which electricity is also supplied to consumers in the Tashkent and Syrdarya regions.

The proposed scope of the "Koltsevaya" substation sub-project is quite large and includes the construction of about 213 km of 220 kV and 72 km of 500 kV overhead transmission lines, as well as a 500/220/10 kV digital substation with 7 single-phase 267 MVA autotransformers (one reserve).

2.5. Sub-project solutions

2.5.1. Main technical specifications

The main technical specifications of the designed substation are given in Table 2.

Table 2: Main technical specifications of the 500 kV substation

Indicators	Specification
Substation type	Digital, open air
Nominal voltage	500/220/10 kV
Number and capacity of autotransformers	7 single-phase three-winding units with a rated capacity of 267 MVA each, including 1 single-phase three-winding standby unit
500 kV switchgear design, scheme	"One-and-a-half-breaker scheme"
220 kV switchgear design, scheme	" Two working sectionalized circuit breakers and a bypass busbar system with two bypass and two bus couplers"
Number and design of 220 kV transmission lines to be connected to switchgear-500	500 kV - 2 overhead lines
	220 kV - 8 overhead lines (in addition, 2 reserve bays are reserved to connect 220 kV overhead line "Koltsevaya - "Sergeli" in future)
Switchgear design -10 kV	10 kV cubicle switchboard cabinets with vacuum circuit-breakers, by scheme - one, sectionalized circuit-breaker, busbar system
Number of cubicle switchboard sections 10 kV	2
10 kV neutral earthing mode	Insulated neutral
Current limiting reactors 10 kV	6 - horizontal installation
Number and capacity of 10.5/0.4 kV auxiliary transformers	3 x (1000-1250) kVA - (capacity to be specified in further design)
Number and capacity of 10 kV booster transformers (LRT)	2 of 16 MVA each
Number of 380/220 V auxiliary sections	2

Indicators	Specification
Number, capacity, battery voltage	2 (capacity to be specified during further design work), 220 V
Number of battery cells	108 voltage 2 V
Number of panels, sections of 220 V DC panel	2 panels, 4 sections, 4 chargers
Reactive power compensation in 500 kV networks	Provided, Reactor-500 kV single-phase, 3x60 MVar
Type of service	With permanent operational staff

The main technical parameters of the sub-project "Construction of 500 kV "Koltsevaya" Substation and two sections of the 500-kV overhead TL (Line in Line out) from the "Syrdarya TPP – "Tashkent" in Tashkent Region" are presented in Table 3 below.

Table 3 Main technical parameters of the sub-project

№	Name of indicators	Unit of measure.	Total
1	Construction of 500/220/10 kV "Koltsevaya" substation with two groups of autotransformers with capacity of 801 MVA (2x3x267 MVA)	unit. substation	1
2	Construction of 500 kV new sections of overhead TL to connect "Koltsevaya" substation as Line in Line out diagram to the line "Syrdarya TPP - "Tashkent-500" (L-502)	km	72 (2x36)
3	Construction of a single-circuit 220 kV overhead TL "L-Feruz-1"	km	43
4	Construction of a single-circuit 220 kV overhead TL "L-Feruz-2"	km	43
5	Construction of double-circuit 220 kV overhead TL "L-Ozodlik-1", "L-Keles-2"	km	42
6	Construction of double-circuit 220 kV overhead TL "L-Ozodlik-2", "L-Keles-1"	km	42
7	Construction of double-circuit 220 kV overhead TL "L-Yuksak", "L-Keles-3"	km	43

2.5.2. Substation master plan

The sub-project provides for:

- **Construction of substation control building (SCB).** The SCB is a two-storey rectangular constructed from bricks building with dimensions of 48.0 x 12.0 m. The height of the premises is 3.0m and 3.6m.
- **Construction of an auxiliary building (AB).** A single-storey rectangular constructed from bricks AB with dimensions of 19.8 x 9.6 m is envisaged to house personnel of the specialized maintenance crew at the substation.
- **Construction of a 10 kV closed switchgear building (CSB).** The CSB is a one-storey rectangular constructed from bricks building with dimensions of 18.0x6.0 m.
- **Construction of the gatehouse.** The gatehouse is a one-storey constructed from bricks building, rectangular in plan, measuring 6.0 x 6.0 m.
- **Construction of an oil pump house.** The oil pump house is a rectangular brick building with dimensions of 9.6x16.8 m.

- **Construction of an outdoor oil storage facility.** The outdoor oil storage tanks are designed to be rectangular in shape. The foundations for the oil storage tanks are monolithic reinforced concrete of concrete class B20.
- **Construction of the Firefighting pumping station.** The firefighting pumping station is a rectangular brick building with dimensions of 6.0×6.0 m.
- **Fire protection tanks.** The works for fire protection tanks include the construction of a monolithic reinforced concrete slab reinforced with frames, the laying of wall panels and a prefabricated reinforced concrete cover slab.
- **Oil collector.** The oil collector is an underground containment structure made of prefabricated reinforced concrete elements, the volume of the oil collector is 100 m³.
- **Water supply.** The source of water supply for the 500 kV "Koltsevaya" substation is a sub-projected underground water intake from two artesian wells (working and reserve), carried out under a separate sub-project. Separate systems of domestic and fire-fighting water line will be designed in the substation area.
- **Sewerage.** The drainage of domestic wastewater from the buildings of the SCB, APC, gatehouse, pump rooms above the artesian wells, and the oil control operating room is carried out into the designed unpressurised sewerage network.

The sub-project also provides for:

- Planning of the territory of the substation by organizing the relief in conjunction with the planning of the adjacent territory;
- Landscaping of the substation site after the completion of all construction and installation works by backfilling the territory of the substation free from structures and roads with crushed stone t=20 cm;
- Installation of an external reinforced concrete fence, with an internal mesh fence, as well as the installation of a gate and wicket;
- Installation of an emergency oil drainage system made of steel pipes and connected to the designed oil collector;
- Arrangement of internal roads with asphalt-concrete pavement and 4.5 m wide carriageway;
- Arrangement of parking area for internal vehicles.
- The drainage of storm and mudflow waters is solved by means of a drainage network along the gradient of the planned area with an outlet outside the substation fence.

2.6. Scope of work

The purpose of this report is to provide an assessment of potential environmental and social risks and issues that need to be taken into account in relation to the construction and maintenance of the subproject. The ESMP is based on the principles, rules, guidelines and procedures set out in the Environmental and Social Management Framework for the whole project, and this site-specific ESMP identifies the potentially significant environmental and social impacts of the sub-project "Koltsevaya" 500 and related TL, and determining the appropriate environmental controls, mitigation measures and degree of control.

The site-specific Environment and Social Management Plan (ESMP) is an important document that should be circulated to the key partners prior to sub-project implementation.

The ESMP provides an integrated approach to environmental and social management that has been adopted to confirm the potential environmental and social impacts of the sub-project. The purpose of the ESMP is (i) to identify the potential environmental and social impacts of this subproject and (ii) to detail the measures to be taken during the implementation and operation of the subproject to eliminate or offset adverse environmental and social impacts, or to reduce them to an acceptable level, and (iii) to detail the actions needed to implement these measures; (iv) As well as to allow for meaningful and inclusive multi-stakeholder consultations and engagement throughout the lifecycle of the program.

Environmental and social management provides general and systematic guidance covering policies, procedures and regulations that should be linked throughout the project implementation period to ensure that social and environmental issues are systematically addressed during the project implementation stage. In addition, the ESMP provides technical input and guidance to the Project in terms of environmental and social management. Thus, the application and implementation of the ESMP will guide the integration of social and environmental aspects into decision-making at all stages of project planning, design, implementation, operation and maintenance by identifying, preventing and/or minimizing adverse social and environmental impacts - at the earliest stages of project implementation process.

The proposed substation “Koltsevaya” 500 and related TL construction sub-project is environmentally sound and does not present any major environmental problems that could arise during both the construction and operation phases. One possible way to ensure environmental management during construction and operation is to develop standard operating procedures that take into account safety and environmental issues and ensure compliance by all employees and are monitored by the sub-project engineer.

It is recommended that a contract be concluded with the contractor during the construction phase to minimize short-term environmental and social impacts using known traditional methods such as water spraying to minimize dust, limiting the speed of traffic within the sub-project area, ensuring sufficient toilets for construction workers, properly disposing of household waste (especially food waste) and introducing health and safety regulations. The designated sub-project manager should closely monitor compliance with the environmental, social and safety provisions of contracts.

The overall objectives of environmental and social management are:

- Implementation of measures to prevent or reduce any negative impact to the acceptable levels;
- Implementation of measures that contribute to ensuring environmental measures coinciding with technical and other sub-project activities during implementation;
- Implementation of measures to eliminate risks at construction and operation stages;
- Monitoring and control of significant problems during construction and operation.
- Developing mechanisms for compliance monitoring.
- Minimizing adverse social impact (e.g. labor relations, relations to surrounding communities, gender issues and etc.)
- Arrangement of adequate channels of input for the different stakeholders throughout the sub-project activity.

3. Policy, legal and regulatory frameworks for Environmental and Social Assessment

3.1. National environmental and social legislation of Uzbekistan and procedures

Environmental and social impact of the Project is regulated by a number of environmental and sociological legislative acts of the Republic of Uzbekistan. In accordance with Article 11 of the Law of the Republic of Uzbekistan "On Environmental Expertise", the project requires EIA preparation.

Legislation provides for a number of other environmental rights and obligations of citizens, which may be implemented through individual or public environmental protection activities.

Table 4. List of environmental laws relevant to the project

Year	Law / Regulation	Last revision
08.12.1992	Constitution of Uzbekistan	16.04.2014
09.12.1992	Law "On nature protection"	18.04.2018
06.05.1993	Law "On water and water use"	23.07.2018
23.09.1994	Law "On Subsoil"	13.12.2002
25.05.2000	Law "On Environmental Expertise";	14.09.2018
03.12.2004	Law "On protected natural areas"	14.09.2017
26.12.1997	Law "On protection and use of flora"	21.09.2016
26.12.1997	Law "On protection and use of fauna"	19.09.2016
27.12.1996	Law "On air safety"	14.09.2017
05.04.2002	Law "On wastes"	10.10.2018
12.11.2013	Law "On Environmental Control"	12.11.2013
28.08.1998	The Law "On the State Land Cadastre"	03.12.2004
23.09.1994	Law "On Subsoil" № 2018-XII	13.12.2002

3.2. Requirements for social assessment

The **Social Assessment** is the process of data collection and analysis, undertaken by the Receiver to identify the social impacts and dimensions of investment projects, provide spaces to incorporate stakeholders' views into project design, and to establish a participatory process for implementation, monitoring and evaluation. The World Bank might require the Receiver to conduct a full Social Impact Assessment in cases where large scale or serious sociological or socio-economic impacts are expected or there is a lack of baseline socio-economic data.

The national legislation of Uzbekistan does not contain any requirements regarding SA, so in case the SA will be requested, the EA will organize the process of SA based on Bank's recommendations. The only national regulatory document that can be applied to SA is the Resolution of the Cabinet of Ministers of February 15, 2013 № 44 "On approval of the Regulations on the assignment and payment of social allowances and financial assistance to low-income families" as amended in accordance with the CM Resolution № 1046 of December 28, 2019.

Table 5. List of social property and land ownership laws relevant to the project

Year	Law / Regulation	Last revision
29.08.1996	Civil Code of Uzbekistan	18.04.2018
21.12.1995	Labour Code	16.10.2018
25.12.1997	Tax Code	11.10.2018
30.04.1998	Land Code	24.07.2018
13.01.1992	Employment Act	03.01.2018
30.08.2001	Law on Cultural Heritage	18.04.2018
29.08.1996	Law on Public Health	13.06.2017
01.08.2018	Decree of the President of the Republic of Uzbekistan № 5495 "On measures on cardinal improvement of investment climate in the Republic of Uzbekistan"	01.08.2018
25.05.2011	Resolution of the Cabinet of Ministers № 146 on improvement of the procedure for provision of land plots, protection of the rights of legal entities and individuals to land plots for improvement of the architectural appearance of residential areas of the republic, optimal use of their lands for development.	25.05.2011 as amended by Resolution of the Cabinet of Ministers No. 1024 (December 20, 2019)
15.02.2013	Resolution of the Cabinet of Ministers № 44 "On measures for further improvement of the procedure for the appointment and payment of social benefits"	28.12.2019 with amendments based on Resolution of the Cabinet of Ministers № 1046
21.09.2016	Resolution of the Cabinet of Ministers of RUz № 317 "On amendments and additions to some decisions of the Government of the Republic of Uzbekistan, aimed at further improving the procedure for registration of cadastral documentation for real estate"	29.12.2018
30.03.2017	Resolution of the Cabinet of Ministers №165 on the procedure for the appointment and payment by self-governing bodies of lump-sum material assistance to needy families in the Republic of Karakalpakstan and Khorezm region	30.03.2017
16.07.2018	Decree of the Cabinet of Ministers № 3857 "On measures to improve the efficiency of the preparation and implementation of projects involving international financial institutions and foreign public financial organizations".	16.07.2018
27.07.2018	Presidential Decree № 5490 "On measures for further improvement of the system of protection of rights and legitimate interests of business entities".	27.07.2018

Year	Law / Regulation	Last revision
26.12.2018	Resolution of the Cabinet of Ministers of RUz № 1047 "On the procedure for the formation and use of centralized funds to compensate for the damage caused to private individuals and legal entities in connection with the withdrawal of land plots for the needs of the state and society"	26.12.2018
10.05.2018	Resolution of the Cabinet of Ministers of the Republic of Uzbekistan dated May 10, 2018 № 349 "On additional measures to eradicate forced labor in Uzbekistan"	10.05.2018
13.08.2019	Law of the RUz № 552 "On Privatization of Non-Agricultural Land".	13.08.2019
03.08.2019	Decree of the President of the Republic of Uzbekistan № 5491 "On additional measures to unconditionally guarantee the property right of citizens and business entities".	03.08.2019
16.11.2019	Resolution of the Cabinet of Ministers № 911 "On the procedure for acquisition of land plots and compensation to owners of real estate located on the withdrawn land plot".	16.11.2019
11.12.2019	Resolution of the Cabinet of Ministers of the Republic of Uzbekistan № 981 "On approval of the regulation on the procedure for establishing water protection zones and sanitary protection zones for water bodies in the Republic of Uzbekistan".	11.12.2019

3.3. National requirements for Environmental Impact Assessment (EIA)

The national ESA procedure is regulated by the Law "on Environmental Expertise "(2000), updated on 14.09.2017, and Cabinet of Ministers Resolution № 541 of 07.09.2020: "On Approval of the Regulation on State Environmental Expertise". In accordance with Article 3 of the aforementioned law, an environmental impact assessment shall be carried out to identify:

- Compliance of the planned economic and other activities with environmental requirements at the stages preceding the decision to implement them;
- The level of environmental hazard from planned or existing economic and other activities which may have or have had a negative impact on the environment and public health;
- Adequacy and validity of the measures envisaged for environmental protection and rational use of natural resources.

The following activities require EIA implementation:

- projects of state programs, concepts, layouts and development schemes for productive capacities, economic sectors and social sphere;
- when selecting land plots for all types of construction;

- pre-project and design documentation;
- projects of normative-technical and instructive-methodical documents regulating economic and other activities related to the use of natural resources;
- documentation on creation of new types of equipment, technologies, materials, substances and products;
- active enterprises and other facilities that have a negative impact on the environment and citizens' health;
- all kinds of town planning documentation;
- objects with special legal regime.

After preparation of the EIA, the State Committee for Ecology and Environmental Protection (SCEEP) is considered a special authorized state body in the field of state environmental expertise.

3.4. World Bank policy requirements for environmental and social assessment

The level of detail of the environmental analysis depends on the scale and impact of the proposed works on the environment and the social environment. Four risk categories are given below: **high, substantial, moderate or low**. When assigning the risk category, relevant factors such as the type, location, sensitivity and scale of the project; the nature and extent of potential socio-environmental risks and impacts; and the Receiver's facilities and determination to manage socio-environmental risks and impacts in accordance with the ESS are taken into account. Depending on the nature of the project and the context in which it is being developed, other risk factors may also compromise the implementation of mitigation measures. These may include legal and institutional aspects; the nature of the proposed measures and technologies; governance structures and legislation; and factors relating to stability, conflict or security.

- **High risk (HR)**. A project is classified as HR if it is likely to have significant adverse effects on the environment (depending on the type, location, sensitivity and scale of the project and the nature and magnitude of its potential environmental impacts). These effects are generally irreversible, sensitive, diverse, cumulative or precedent-setting, and may affect areas outside the project sites or facilities.

There are several locations that should be taken into account when deciding whether a project should be classified as a **HR** project:

- in or near sensitive and valuable ecosystems - wetlands, fertile land and habitats of endangered species.
- in or near areas where there are archaeological and/or historical sites or existing cultural and social institutions;
- in densely populated areas where resettlement may be required or potential impacts, pollution and other disturbance may have a significant impact on the population;
- in areas subject to complex development activities or conflicts in natural resource allocation; along watercourses, in aquifer recharge areas or in catchments used for drinking water supply; and on lands or waters containing valuable resources (such as fish resources, minerals, medicinal plants, agricultural soils with a high degree of bone deposit).

- **Substantial risk (SR)**. A project is classified as **SR** if the potential environmental impacts, usually site-specific, are reversible in nature; the damage is less than in **HR** category projects, and if mitigation measures can be more easily developed. **SR** category projects sometimes differ only in scale from **HR** category projects.

- **Moderate risk (MR)**. A project falls into the **MR** category if it is likely to have minimal or no negative impact on the environment. For example, technical assistance projects in the areas

of institutional development, computerization and training are categorised as **MR**.

- **Low risk (LR)**. A LR category project involves minimal or no impact.

3.5. Recommended Sub-project Categorization

Given the location of the new substation at a distance of 1000 m from residential buildings and the lack of infrastructure (roads, markets, etc.) close to the substation, minor impacts with irreversible consequences are foreseen during the construction period. However, the overall social impacts, in terms of the land acquisition are permanent and irreversible (land acquisition), therefore the development of the ESMP should focus on specific environmental/social issues.

Accordingly, following the World Bank standard on the impact of social and environmental risks ESS 1, the 500 kV "Koltsevaya" substation and related TL construction subsub-project is categorized as **Substantial (SR)**.

The environmental impacts may affect only the area, sites or facilities subject to physical works. These impacts are limited to individual project locations; there are few or no irreversible effects; in most cases mitigation measures are easier to develop.

3.6. World Bank ESF Requirements

Based on the WB Environmental and Social Framework (ESF), an Environmental Assessment (EA) should be carried out during project design. At this stage, potential environmental and social risks are assessed and the impact area of the project is defined. It allows the exploration of project alternatives; site selection, planning and design of adverse environmental impacts. Preliminary EA allows the development of preventive and mitigation measures to manage adverse environmental impacts.

The following environmental and social standards (ESS) are relevant to sub-project:

3.6.1. ESS1: Assessment and Management of Environmental and Social Risks and Impacts

ESS1 sets out the Client's responsibilities for assessing, managing, and monitoring environmental and social risks and impacts associated with each stage of a project supported by the Bank through Investment Project Financing, in order to achieve environmental and social outcomes consistent with the Environmental and Social Standards (ESSs).

Overall, the sub-project will have a number of positive social and environmental impacts. It supports technical assistance and energy capacity building activities, reduces the operating costs of substation equipment; the consumption of electricity for own and household needs of substations; increases transformer capacity; increases the reliability of electricity supply to consumers throughout the Republic's energy system, ensuring a safe, reliable and affordable electricity supply for households.

However, activities during the period of construction of new transmission substations and lines may result in adverse impacts and therefore the sub-project will need to introduce substantial environmental and social pre-screening, mitigation and monitoring systems.

3.6.2. ESS2: Labor and Working Conditions

ESS2 recognizes the importance of employment creation and income generation in the

pursuit of poverty reduction and inclusive economic growth. Receivers can promote sound worker-management relationships and enhance the development benefits of a project by treating workers in the project fairly and providing safe and healthy working conditions. ESS2 applies to project workers including full-time, part-time, temporary, seasonal and migrant workers.

The sub-project includes direct workers (employees of NEGU) as well as contracted workers (employees of contractors). NEGU and sub-project beneficiaries conducted screening for primary suppliers to ensure that they have no history of forced and child labor or other significant labor, environmental and social violations.

3.6.3. ESS3: Resource Efficiency and Pollution Prevention and Management

ESS3 recognizes that economic activity and urbanization often generate pollution to air, water, and land, and consume finite resources that may threaten people, ecosystem services, and the environment at the local, regional, and global levels. The current and projected atmospheric concentration of green- house gases (GHG) threatens the welfare of current and future generations.

Assessment of associated with civil works risks and impacts and proposed mitigation measures related to relevant requirements of ESS3, including raw materials, water use, air pollution, hazardous materials, and hazardous waste included the relevant ESMP.

3.6.4. ESS4: Community Health and Safety

ESS4 recognizes that project activities, equipment, and infrastructure can increase community expo- sure to risks and impacts. In addition, communities that are already subjected to impacts from climate change may also experience an acceleration or intensification of impacts due to project activities.

To address environmental risks and impacts that might affect community Health and Safety, the ESMP includes assessment of work related health risks; works and traffic safety; excessive noise and dust levels, site safety awareness and access restrictions; and labor influx and use of security personnel.

3.6.5. ESS5: Land Acquisition, Restrictions on Land Use and Involuntary Resettlement

ESS5 recognizes that project-related land acquisition and restrictions on land use can have adverse impacts on communities and persons. Project-related land acquisition or restrictions on land use may cause physical displacement (relocation, loss of residential land, or loss of shelter), economic displacement (loss of land, assets, or access to assets leading to loss of income sources or other means of livelihood), or both.

Additional land allocation (permanent and temporary) is required for construction of the substation and transmission line, a permanent allocation of 30 hectares is required for construction of the substation. Construction of the transmission line will require temporary and permanent allocation of farm land in Tashkent and Syrdarya regions. Due to the fact that about 120 farms will be affected by the sub-project, Social Audit is being conducted to ascertain the process and compensation is compliant with requirements under World Bank Environmental and Social Standard no. 5 on Land Acquisition, Restrictions on Land Use and Involuntary Resettlement

3.6.6. ESS6: Biodiversity Conservation and Sustainable Management of Living Natural Resources.

ESS6 recognizes that protecting and conserving biodiversity and sustainably managing living natural resources are fundamental to sustainable development. Impacts on biodiversity can therefore often adversely affect the delivery of ecosystem services. ESS6 recognizes the importance of maintaining core ecological functions of habitats, including forests, and the biodiversity they support.

The activities envisaged by the sub-project as part of the substation and transmission line construction will take place on farms in the Tashkent and Syrdarya regions - hence the impacts on biodiversity will be minimal. An assessment of construction-related risks and impacts on biodiversity and proposed mitigation measures associated with the relevant requirements of ESS 6 are included in the ESMP.

3.6.7. ESS8: Cultural Heritage;

ESS8 recognizes that cultural heritage provides continuity in tangible and intangible forms between the past, present and future. It sets out measures designed to protect cultural heritage throughout the project life cycle.

Project activities are expected to have small impact on physical cultural resources, indirect impacts of project-funded activities and mitigation measures will be carefully examined, as well as appropriate 'chance finds' procedures which are included in the ESMP.

3.6.8. ESS10: Stakeholder Engagement and Information Disclosure.

This ESS recognizes the importance of open and transparent engagement between the NEGU and project stakeholders as an essential element of good international practice. Effective stakeholder engagement can improve the environmental and social sustainability of projects, enhance project acceptance, and make a significant contribution to successful project design and implementation.

During the preparation of the ESMP, initial consultations were held with stakeholders and affected communities in April 2021. Issues and concerns raised during the consultations were reflected in the ESMP documents.

4. Environmental and Social Impact Assessment and mitigation measures

4.1. Environmental Impact Assessment Methodology

The purpose of the ESIA is to determine the baseline environmental conditions with a view to identifying and assessing the impact of the various activities of the proposed project. This report contains an abbreviated ESIA, and an Environmental and Social Management Plan (ESMP) and an Environmental and Social Monitoring Plan (ESMoP).

Potential environmental impacts were assessed in accordance with World Bank policy and environmental legislation of the Republic of Uzbekistan, and the ESMF of the project. In addition, organizational aspects were taken into account.

4.2. Impact Screening

Screening is used to determine the degree of environmental studies required for the project. This screening is conducted in accordance with the checklist contained in the World Bank's Environmental Assessment Handbook. Using criteria such as project type, scale and location, environmental sensitivity and the scale of impacts, the purpose of the checklist is to filter out minor impacts and to focus on those impacts that require mitigation measures.

The purpose of mitigation is to prevent or reduce any potential adverse impact on the environment. There are various alternatives to mitigate certain effects. Therefore, the choice of mitigation methods should be a joint process between engineers and environmentalists. The methods used must be economically feasible and the best available. Collaboration and monitoring is necessary to ensure that the method is implemented correctly.

Each environmental factor that may be affected by project implementation has been reviewed and the scale and importance of each potential environmental impact has been assessed. The following definitions of the significance of impacts have been used in the environmental impact assessment:

No impact - potential impact is assessed as zero if the project activity is physically remote in space or time from the environmental component, or if the impact is so low that it cannot be measured (i.e. minor). No mitigation measures are required for a project activity that will have "no impact";

Minor impact (positive or negative) - if an impact occurs but does not meet the criteria for significant impact, it is considered minor. For minor adverse impacts, appropriate mitigation measures shall be taken;

Major impact (positive or negative) - a major impact is significant if the project has the potential to affect the environmental component. The following criteria are used to determine whether an impact is significant; (i) the spatial scale of the impact (project area, local, regional or national/international); (ii) the time scale of the impact (short, medium or long term); (iii) the scale of change in the environmental component caused by the project activity (small, moderate, severe); (iv) the significance for local communities; and (v) compliance with international, national, regional or district conservation laws, standards and regulations; and (vi) compliance with Uzbekistan and World Bank guidelines, standards and regulations. Where potentially serious adverse impacts are identified, measures are developed to mitigate their impact to acceptable levels.

Unknown impact - potential impacts from project activities will be assessed as unknown if the severity of the impact cannot be determined for one of the following reasons: (i) the nature and location of the project activity is uncertain; (ii) the environmental component of

the study area is uncertain (iii) the time scale of the impact is unknown; or (iv) the spatial scale at which the impact may occur is unknown. Mitigation measures are defined for impacts that are classified as "unknown impacts" where possible.

There are several types of impacts that need to be considered. Direct impacts are caused by project activities, occur at the same time and in the same place and can occur both during construction and during project operation. Direct impacts will be limited in this project because the reconstruction and construction of water supply and sewerage systems are in fact environmental protection measures.

Indirect impacts, which may include growth induced by the project activity or by the project as a whole, occurring later in time or at a longer distance, are still fairly predictable.

Short-term impacts, such as noise and exhaust emissions from heavy machinery, occur during construction activities and do not generally have long-term effects.

Environmental screening identifies a number of potential environmental impacts that may arise from activities proposed for the project. Where environmental impacts are considered severe (or significant), mitigation measures will generally be taken for inclusion in project documentation.

Impacts arising from construction activities are dependent upon a number of factors, including the temporary use of land and its restoration after construction. The use of 'best practice' during construction works, coordination and cooperation with local authorities in terms of impact management, and strict compliance with the environmental regulations included in project proposals and specifications and compliance with the comprehensive ESMP.

The following section describes the environmental impacts that will result from the project. It also describes the mitigation measures that have been developed and which aim to mitigate to a technically feasible minimum.

The description divides the different phases of the project, design, construction and operation. Ultimately, all proposed construction-related mitigation measures will be included in tender or contract documents, which will be a mandatory element of construction and construction supervision contracts.

4.2.1. Impacts and Mitigation Measures - Design Stage

This chapter presents various design options that have been considered from an environmental perspective. As part of the planning process, the selected sites were reviewed in close collaboration with the sub-project team. This interactive planning process aims to prevent and minimize potential impacts to the extent technically feasible. The main points to be considered are the following:

- Loss of vegetation cover
- Loss of agricultural land
- Impact on existing settlements
- Impacts on flora and fauna
- Impact on landscape

The following options were compared at the design stage:

No negative impacts are expected during the design stage. Some surveying is required during the design stage, but no environmental impacts are expected.

4.2.2. Impacts and Mitigation Measures - Construction Stage

During the Construction of Substation "Koltsevaya" 500 and related TL, the greatest impact on the environment is related to civil works. The nature of the environmental impact during and after civil works will change.

The technological process of power transmission and distribution over overhead TL is waste-free and does not cause harmful emissions into the surrounding air or water environment.

The routes of the designed overhead TL have been selected with due regard to the requirements of land users and the least possible damage to the environment.

The supports will be placed taking into account the maximum possible conservation of fertile land and greenery. Orchards will not be cut down.

To protect birds from electric shocks, anti-bird barriers are installed above all supporting garlands.

The parameters of supports, wire cross-sections, distances between phases and between phases and ground ensure the level of electric field intensity that meets international requirements and exclude corona on the wires. Dimensions from conductors to the ground and other structures are taken according to EIC and biological norms.

In the event of possible damage to the overhead TL leading to an accident (falling of support or wire breakage), there will be no adverse impacts on dwellings due to the overhead TL passing away from residential buildings at a distance greater than the height of the support.

All technical solutions for this sub-project are taken in full compliance with the applicable regulations to ensure the safe operation of the overhead TL.

During excavation work for installing foundations on cultivated land, the fertile soil is placed aside, separate from the other excavated soil and then placed back onto the surface of the backfill.

If the recommendations and measures that will be given in the detailed design after the detailed surveys are followed, there will be no negative impacts on the atmospheric air, surface and ground water, soil, vegetation and population.

The construction of the Substation "Koltsevaya" 500 will lead to small environmental impacts during their implementation, both positive and negative.

The use of modern, high-efficiency power equipment in the sub-project substation minimizes the environmental impact.

The following environmental protection measures are envisaged in the design of the substation:

a system of closed oil drains and oil collector to prevent pollution of the surrounding area and water bodies in case of emergency release of oil from autotransformers;

use of sulfur hexafluoride (SF₆) circuit breakers 500, 220 kV circuit-breakers that comply with international standards;

No noise protection measures for the surrounding area are required, as the residential area is outside the footprint of noise from the autotransformers;

The cross-sections of the wires have been selected to check for corona and practically ensure that there is no noise;

Fire-fighting measures are provided;

Land remediation is not required.

The implementation of the sub-project solutions has virtually no negative impact on the environmental components of the area.

The source of air pollution at the substation is transformer oil tanks. The surface concentrations of hydrocarbons contained in the substation emissions at the boundary of the substation do not exceed the established quotas.

Impacts on soils and land cover occur within the substation site during construction of

buildings and structures. The impacts are of a reversible, one-off nature. A minor impact on soil and vegetation cover occurs during construction of the overhead TL incoming lines into the substation.

Water at the designed substation is used for domestic purposes only. Fire-fighting tanks are provided for fire-fighting purposes. The source of water supply is a well.

The physical impacts of substation operation are localized within the substation site and do not affect the population of the nearby communities.

Harm to the environment must be controlled mainly in relation to:

- contamination of soil, surface and ground water through spills of fuel, oil and lubricants;
- health of workers and local communities involved in the construction and operation of machinery;
- collection of waste generated at construction sites;
- environmental disturbance of biocoenosis and habitats of birds and other animals;
- - air pollution through emissions of harmful substances;
- preservation of architectural monuments.

Mitigation measures are outlined below.

Environmental precautions during construction

The main environmental impact will be related to construction work. Environmental due diligence is required to control the risks of accidental environmental damage and to prevent the environmental impact of the impact to the greatest extent possible:

- for complex facilities and special works, it is mandatory to develop the components of the work sub-project.
- introduction of new effective materials and structures, technologies of work performance in construction production.
- provide for the creation of safe and healthy conditions that facilitate work and exclude accidents and accidents, ensuring occupational safety rules with the right choice and technically justified size of workplaces and their organization.
- commissioning of facilities that do not meet environmental requirements is prohibited.
- determine the sequence of construction work, keeping local nuisances to a minimum.
- identify construction methods using fencing of work areas. Ensure adequate access to work and living areas as much as possible.
- require the contractor to guarantee the safe movement and installation of the machinery.
- require the contractor to use traffic diversion in the work area if necessary. Traffic control, emergency signals and lighting should be installed according to local regulations. Provide safe bypasses and crossings for pedestrians where necessary.

All this is the responsibility of the contractor and the construction supervision services.

4.2.3. Impacts on land resources

Additional land acquisition (permanent and temporary) is required for substation and transmission line construction, a permanent land acquisition of 30 hectares is required for substation construction. Construction of the transmission line will require temporary and permanent land acquisition of farms in Tashkent and Syrdarya regions. Therefore, about 120 farms will be affected by the subsub-project.

Table 6. Preliminary data on land acquisition and number of affected farmers in Tashkent region

Tashkent region	Yangiyul	Zangiota	Pskent	Okkurgan	Kuyu-chirchik	Total by region
Temporary (ha)	70,82	59,02	48,19	39,9	131,5	349,43
Permanent(ha)	1,1151	0,702	2,59	2,25	3,57	10,2271
Number of farmers	22	41	28	5	7	103
Total	71,94	59,72	50,78	42,15	135,07	359,66

Table 7. Preliminary data on land acquisition and quantity of affected farmers in Syrdarya Region

Syrdarya region	Hectare(ha)	Total by region
Temporary	21,3096	21,31
Permanent	0,2418	0,24
Number of farmers		15
Total	21,5514	21,55

In connection with the above data, it is necessary to conduct a Social Audit to ascertain that the process and compensation is compliant with requirements under World Bank Environmental and Social Standard №5 on Land Acquisition, Restrictions on Land Use and Involuntary Resettlement, and recommend the implementation of any additional measures to fill the gaps between the existing process and WB requirements, before any construction work may start.

Soil erosion and slope instability should be addressed by backfilling trenches, terracing hillsides, planting trees and building sediment retention dams.

The contractor should take all practicable measures to prevent degradation and erosion of the soil, nearby streets, access roads, orchards and fields. The use of heavy machinery should be limited as far as possible to avoid disturbance and compaction of farm land around the substation and transmission lines.

The main impact on land resources is the contamination of the soil with construction waste and lubricants, cesspool waste, as well as flooding of adjacent lands with possible structural damage. Appropriate sites should be prepared for the collection and storage of construction waste and sediments to reduce the negative impacts on the environment.

During construction of the substation and foundations for the supports, organic topsoil suitable for further use shall be removed and temporarily stored separately from the remaining soil materials.

During construction, excavation and backfilling, land levelling, preparation of oil sump tank foundations and equipment foundations will be carried out.

Earthworks will be carried out using excavators and bulldozers. During excavation the soil

will be stockpiled near the trenches and excavation pits. The excavation shall be used as much as possible as backfill and embankment. Surplus soil represents waste material and will be used in land levelling. More detailed mitigation measures will be provided below in the Environmental and Social Management Plan (ESMP).

4.2.4. Waste generation

The following waste will be generated during civil work:

- Soil waste from the preparation of sites for the construction of substation buildings and infrastructure and foundations for transmission towers, which will be partly used for backfilling of trenches and pits as well as for site levelling;
- Waste metal materials after construction will be delivered to "HUDUDIY IKKILAMCHI QORA METALLAR" LLC (Vtorchermet) or for recycling to the metallurgical plant.

Maintenance of equipment will be carried out exclusively at gas stations, used oils and other liquid pollutants will be stored in specially equipped places for them and taken out for regeneration at the nearest oil depot.

Storage of such waste in areas close to populated areas and untimely or inappropriate disposal can affect air quality, dust generation and affect neighboring communities. In addition to this waste, used welding rods, packaging materials and wood will also be generated. Construction waste as well as other waste (paper, glass, plastic, etc.) should be classified into separate containers. Waste disposal sites should be carefully selected at the construction site, and waste classification and recycling rules should be prepared in environmental management plans.

The following types of waste will be generated during substation operation and repair works: scrap ferrous metal, scrap aluminium; scrap copper, scrap lead, scrap brass, scrap rubber, waste silica gel, waste transformer oil, waste compressor oil, welding electrode stubs, cleaning material contaminated with oil products (oil content less than 15%), uncontaminated paper waste, waste paper and paper filters, waste LED lamps (not containing mercury). Municipal waste is expected to be generated from staff activities.

Hazardous waste

The most hazardous waste generated during construction includes spent fuel and lubricants. These wastes are hazardous pollutants of almost all components of the natural environment - surface water, groundwater, land cover, atmospheric air. They can cause significant environmental damage during improper collection and storage. Therefore, it is necessary to observe the conditions of their collection and storage.

When installing containers with burnup fuel and lubricants, the places for the accumulation of this waste should have a solid cover and a canopy, which excludes the penetration of water and foreign objects. Tanks with used oil and contaminated oil products must be equipped with metal pallets. The tray shall be capable of holding the oil in case of an overflow of at least 5% of the volume. The places and sheds where used oil containers are stored must be protected. When storing used oil containers, care must be taken to avoid contaminating the environment with used oil (drum plugs must be tightened).

Wastes of fuel and lubricants should be disposed of at the nearest oil depot as they accumulate. Asbestos-containing materials (ACM) will not be used during sub-project implementation. The transformer oil will not contain polyvinyl chloride (PVC). Hazardous wastes should be stored in certain safe places as defined in the waste management plan.

4.2.5. Impacts on water resources, soil, grounds

Excavation work, oil leakage, improper storage of hazardous materials, construction waste and household waste can lead to chemical contamination of soil, ground, surface and ground water. In the event of an accidental spill, immediate cleaning will take place. Contamination can be caused by wastewater if it is discharged into pit latrines without adequate protective waterproofing layers. All cleaning materials must be stored in a safe place in a separate area of the construction site where the disposal of hazardous waste is permitted. Measures to protect against contamination of surface water, soil and ground should be included in environmental management plans.

In case of non-compliance with the rules of work with lubricants during construction works the condition of soils, soil, surface and ground waters will be disturbed. This impact will be temporary and will have reversible effects on these environmental components.

A plan for the prevention of surface and groundwater and soil pollution is presented below in the Environmental and Social Management Plan (Chapter 6, Table 6).

4.2.6. Impact on atmospheric air

Temporary environmental impacts from construction activities are associated with the use of construction equipment and excavation works. During the execution of the earthworks sub-project activities, atmospheric air will be impacted through the introduction of inorganic dust from the ground surface and combustion products of diesel fuel (carbon monoxide, nitrogen oxides, hydrocarbons, soot, aldehydes, benz(a)pyrene) from construction equipment and vehicles. Excavation of rock will be carried out using a bulldozer and excavator. The work of the bulldozer and loading will be accompanied by the emission of inorganic dust with SiO₂ content of 20-70% into the atmospheric air. The dust will increase around the construction site and the transportation route around 100-150 meters from the road. The construction site, bypass road, soil dump as well as the operation of construction equipment will become sources of dust. Dust will be generated from open areas for storage of topsoil, sand, soil transport vehicles and sand if they are not covered.

During the construction phase of the sub-project, there will be impacts on air quality due to construction equipment exhaust and dust generation, but these impacts will be localized and temporary. In particular, the risk of dust pollution will increase during windy weather. The impact will increase when construction/renovation works are undertaken in the vicinity of populated areas.

Given the nature of most activities, these impacts are expected to be short-term, low risk and reversible and can be mitigated by implementing the measures recommended in Table 6. However, the application of additional measures (most often watering, dust screen installation) may be required for facilities associated with excavation works, when transporting dusty materials. Particular care should be taken when coming into contact with toxic asbestos dust, which can be generated when dismantling the roof of the SCB building and pump house, made of asbestos sheets. Personnel should wear protective masks. Guidelines for working with asbestos materials and precautions are given in Annex 3. Negative effects can be prevented by applying best construction practices and appropriate mitigating measures.

4.2.7. Noise and vibration impact

Civil works during substation and TL construction using special equipment, transport trucks, earthworks will create noise and vibration in the nearby old buildings, restrict access to the buildings, close parts of the roads and disrupt vehicular traffic along them. The noise footprint will be up to 50 m from construction work areas (dismantling and installation sites for equipment and major repair works). It is not expected that noise levels may exceed the established standards during sub-project activities. Noise impacts can be mitigated through

the use of recommended measures. Given the specific nature of the sub-project works, vibration is not expected to affect human health and the integrity of the structures, as no works generating noticeable vibration will be carried out.

Noise and vibration impacts will not affect houses, social facilities as they are at least 1000m away when working in the substation area. The construction camp will be temporarily inhabited by construction workers and therefore all works with increased noise must be carried out during daytime hours.

Sanitary Regulations and Norms № 0267-09 are used in Uzbekistan to ensure acceptable noise levels for residential areas. These rules and regulations establish permissible noise parameters for residential and public buildings and residential development of inhabited areas created by external and internal sources and the noise level should not exceed 55 dB(A) during the day and 45 dB(A) at night.

The sub-project must also comply with the sanitary regulations and rules 0120-01 to ensure an acceptable level of noise in the workplace. Noise reduction measures should be presented in an environmental management plan.

In order to reduce the adverse effects of noise in the workplace, workers must wear personal protective equipment - anti-noise equipment that meets the requirements of GOST 15762-70, if it does not contradict the requirements of safe work performance.

4.2.8. Impacts on vegetation and wildlife

During the construction phase, land cover will be indirectly affected by dust settling on the leaf surface and emissions from the combustion engines of the machinery.

Taking into account that the effects of air and soil pollution by chemicals in the area adjacent to the worksite are acceptable, weak in terms of degree and intensity, and the level of pollution will not exceed the permissible norms, the negative impact on land cover will be short-term and weak in terms of time.

Due to the fact that the works will be carried out on agricultural land which lacks valuable tree species and vegetation listed in the Red Book of Uzbekistan, significant damage to vegetation during construction works is not expected. An observation of the sub-project area revealed that the vegetation is sparse and the areas are irrigated farmland.

Impacts on some groups of animals and birds are expected along the entire length of the route during construction works and operation of the overhead line. The intensity, degree and scale of impact on individual species of fauna will vary due to differences in habitat ecology, food base, life regime.

Habitats of various animals, mainly rodents, lizards, amphibians and fish living in the river and birds nesting in the emergent aquatic vegetation and trees and shrubs growing along the sub-projected power lines will be temporarily disturbed.

Once construction works are completed, the area will attract nocturnal animals as well as birds and reptiles. Thus, the impact on animals will be mild in severity and reversible.

During the operation of 220-500 kV overhead lines, the impact of high voltage can be seen mainly for birds that use the supports for resting and less frequently for making nests. In general, the overhead supports are not favorable places for birds to nest, as the high voltage electric field causes disturbances of some physiological processes.

Negative consequences for birds using overhead line supports for temporary resting occur when they take off and touch the wires and the traverse with their wings. In this case, birds are killed by electric shock.

To prevent death and illness of birds that use OHTL towers for resting and nesting, special bird deterrent devices in the form of ruffs, prickly three-leg trident, spring structures that create temporary vibrating effects are provided on the supports. More recently, special colored umbrellas have been adopted, which are mounted above the strings. They not only deter birds by their bright color, but also protect the strings from being contaminated by droppings, which prolongs the operation of OHTL without additional cleaning and emergency shutdowns.

Direct impacts related to disturbance of dwellings and partly to destruction of foraging habitat may be related to species such as small birds, rodents, medium and small mammals.

Impacts associated with the destruction of animal dwellings will be limited and localized, as the excavation and road-shelf works will occupy small areas. However, areas with dens and other types of animal dwellings will need to be avoided when pads and road shelves are being constructed.

In order to reduce the impact on the young stock during brood rearing and feeding, construction work should be carried out in late summer and autumn.

All fauna groups are expected to be affected by construction noise. Noise impacts from construction equipment will be intermittent, not intense, increasing slightly once the equipment arrives at the site. Due to the gradual increase in the volume of work associated with the arrival of machinery, noise as a disturbance factor will allow animals to migrate a safe distance away from the construction site.

Impacts on ichthyofauna of surface watercourses crossed during construction of the OHTL route are avoided due to the use of a single span crossing, without crossing supports and construction works outside the water area, at 60-100 m from the water edge.

The impact on the animals of the agricultural irrigated area is low in intensity, as there are almost no valuable wildlife species among the agricultural lands. In order to preserve the biodiversity of animals that live near irrigated land and among fields, construction work on the OHTL route should be carried out in spring, before ploughing starts in the areas allocated for spring crops, and in autumn, before the start of agricultural work, in the areas allocated for winter crops.

Mitigation measures will be included in an environmental management plan to minimize impacts on wildlife.

4.2.9. Chance finds (historical monuments or cultural finds)

Historical monuments or cultural objects may be discovered on sub-project sites during excavation works, especially when excavating for the construction of equipment foundations and oil sump tank. A representative of the regional or city Inspectorate for Cultural Heritage Protection will continuously supervise the works on the project sites. In the event of archaeological finds, the Plan requires the publication of special notices, the cessation of work and compliance with excavation procedures.

The contractor is required to continuously monitor the progress of work at the work sites. In the event that archaeological finds are discovered, the contractor shall immediately notify the regional or city Inspectorate for Cultural Heritage Protection.

The Contractor is responsible for protecting any valuable landscapes and sites, including archaeological and paleontological remains. If such remains are found during the works, the "Chance finds" procedure developed within the framework of the ESMP will be applied. An announcement should be made to the relevant authorities and permission should be obtained to continue working after the inventory or inspection of the remains.

4.2.10. Health and safety of workers and community

For workers - Safety and health non-compliance may create a risk for construction workers. The Contractors will have to follow Occupation Safety and Health rules, which include among others strictly implementation established norms and procedure OH&S which depends on type on conducting works, usage of PPE, training activities and monitoring. In addition, all workers need to be introduced to working procedure with hazardous materials. Contractors have to provide workers with appropriate living conditions: safe water supply, washing conditions, rooms for rest and etc.

For community – It is expected that the construction of the substation and 220-500 kV overhead lines will be carried out by the company that won the tender. The approximate number of workers will be around seventy people. The location of the construction camp is not known yet, this information will be determined at the stage of detailed design. Substation and TL construction can be implemented without disrupting the normal livelihoods in any nearby settlements. Contractors will be required to prepare and disseminate a code of conduct and be accountable for its implementation, as well as maintain a grievance mechanisms for their employees. Such measures will be put in place in order to prevent hostile or abusive workplace environment, including issues of sexual exploitation and abuse and sexual harassment. Project training and capacity-building activities will include special modules targeted at GBV to increase understanding of all project staff and key stakeholders of GBV risks and required mitigation measures under the project.

Environmental and social conditions, including the location of settlements and sensitive and protected areas, are being taken into account in the design of project facilities. The contractor shall adequately protect all buildings, structures, works, services or facilities from damage, disturbance or deterioration for the duration of the contract.

Increased truck and vehicle traffic to construction sites and temporary road closures during transportation of oversized equipment within settlements may also cause inconvenience to local communities. Lack of timely and effective disposal of solid domestic waste and inadequate sanitary conditions for construction workers on construction sites and labour camps can lead to environmental contamination and adversely affect the health of local communities. In addition, the movement of heavy equipment can destroy or deteriorate roads within settlements.

The working methods at the facilities under construction can create hazardous situations for workers and the population of nearby communities. A healthy working environment must be created in compliance with health and safety regulations. Work sites and trench bridges must be fenced. Trucks transporting materials and other construction machinery will use the same public road. The risk of traffic accidents with local vehicles, pedestrians will become higher during the construction period.

Traffic control, emergency signals and lighting should be carried out in accordance with local regulations. If necessary, safe bypass roads and pedestrian crossings should be installed.

4.2.11. Traffic and Safety on construction sites

The contractor should plan how to avoid safety problems associated with the movement of traffic and the operation of the excavator at work sites and during the transport of materials. Traffic planning is necessary to minimize the negative impact of sub-project transport on all communities affected by construction. This includes measures to minimize the disturbance of existing road infrastructure, adjacent communities and natural resources, as well as measures to prevent damage to household and community property.

The planning of roads, as well as safe workplaces, parking lots and maintenance areas for trucks and excavators, must be carried out prior to the start of work. Planning includes access routes and entry points to the construction site without affecting households and associated structures, cultivated land, fruit trees or any other potential source of income. Access to commercial and residential real estate should be preserved.

The Contractor shall provide, install and maintain such road signs, road markings, lanterns, barriers and traffic lights and such other measures as may be necessary to ensure road safety around the Sub-project construction sites. Some existing public or private roads or footpaths may need to be closed or diverted for either long or temporary construction periods in order to carry out restoration work. Residents of communities affected by road traffic are advised to provide sufficient information on the impact of traffic characteristic of the sub-project. Where roads that children use to reach schools are used to ensure road safety, road safety education should be provided in schools.

During the construction phase of the Sub-project, air pollution in the form of dust may occur as a result of the movement of trucks. This problem can be solved by limiting the speed of 30 km/h on untreated roads in dry conditions. Injuries or accidents resulting from road traffic accidents should be prevented by planning the terrain, warning signs, fences and driver training. Environmental and safety training for drivers should also include emergency response.

4.2.12. Magnetic field impact

During OHTL operation, the expected maximum magnetic field strength will be 7.76 A/m, which is well below the permissible standards. The MPLs for magnetic field strength are based on occupancy. In accordance with hygienic requirements, eight hours' stay of personnel in a magnetic field of intensity up to 80 A/m for general exposure (to the whole body) and up to 800 A/m for local exposure (to extremities) is allowed).

Consequently, the impact of the overhead transmission line on the environment in terms of magnetic field strength is within the norm, no measures are required to protect personnel and the public from the magnetic field generated by EMF sources from the overhead transmission line wires.

4.2.13. Electric current impact

Electrical currents can affect personnel working during construction and substation maintenance personnel during potential removal from earthing equipment when short-circuit currents and lightning currents are flowing through it. The damaging effect of electric current on the human body is characterized by the cessation of heart, respiratory and nervous system operation and in extreme cases it can lead to death. According to GOST 12.1.038-82 the norm of electric current passing through human body without any harmful effect on health is 0.3 mA in case of accident-free operation of electrical equipment and 6 mA - in case of emergency operation and duration of impact more than 1.0 sec.

4.2.14. Pollution of surface watercourses, groundwater, soils

Earthworks, oil storage, storage of hazardous materials will be sources of river water pollution if the watercourse is nearby. Oil spill, improper storage of hazardous materials, construction debris and household waste can cause chemical contamination. All fuel and chemical storage areas (if any) should be sealed inside the bund and protected by fencing. The storage area shall be located away from any watercourse or wetlands. The base and walls of the bund shall be impervious and have sufficient capacity to contain 110% of the volume of the tanks. Disposal of lube oil and other potentially hazardous liquids into the ground or water bodies is prohibited.

In the event of an accidental spillage, immediate clean-up will be carried out. All treatment materials must be stored in a safe place at a site where hazardous waste disposal is permitted. The surface water treatment plan must be carefully planned during the feasibility study to meet the discharge water quality standard. A sedimentation basin, neutralization tank, reserve pond should be prepared taking into account flooding. All activities will be included in the ESMP.

4.2.15. Impacts and Mitigation Measures - Operation Stage

The construction of the Substation "Koltsevaya" 500 and related TL is expected to increase the coverage of the population with uninterrupted power supply, which will have a positive impact on the living standards of the population and business development.

The 500 kV "Koltsevaya" substation has the technical capability to transfer up to 1,602 MVA of capacity, with an annual transmission of up to 4.5 billion kWh of electricity to consumers, depending on the operating mode of consumers and power plants.

During the operation stage, the following types of waste will be generated at the substation site: ferrous metal scrap, aluminium scrap; copper scrap, lead scrap, brass scrap, rubber scrap, waste silica gel, waste transformer oil, waste compressor oil, welding electrode stubs, cleaning material contaminated with oil products (oil content less than 15%), uncontaminated paper waste, waste paper and paper filters, waste LED lamps (not containing mercury). Municipal waste is expected to be generated from staff activities.

Noise impact will not exceed the normative values: 45 dBA in residential areas according to KMK 2.01.08-96 and 80 dBA in workplaces during operation of power substations according to SanPiN № 0325-16 "Sanitary norms of permissible noise levels in workplaces".

There will be no **atmospheric pollution** after completion of construction works. During the operation of the substation, oil hydrocarbons are released from the non-densities during the operation of the oil-filled equipment (current transformers, voltage transformers, reactors). In order to compensate for the loss of oil hydrocarbons due to evaporation from non-densities, oil topping up is carried out. The release of hydrocarbons into the atmosphere is not organized.

Security forces - It is envisaged that during the operational stages of the substations, State Security Service personnel will be contracted to ensure the security of personnel and assets of the substation. NEGU will assess the risks posed by these security measures to those inside and outside the substation area. In order to manage any such risk, NEGU will be guided by the principles of proportionality and Good International Industry Practices (GIIP) and applicable national law and regulations such as Cabinet of Ministers Resolution № 60 of 1 March 2012. NEGU will not sanction any use of force by security forces except when used for preventive and defensive purposes in proportion to the nature and extent of the threats.

Work in the substation facilities may involve confined space operations in the pump house, transformers, etc.

To prevent, minimize and control accidents and injuries in the substation, appropriate measures are recommended and presented in the environmental and social management plan.

Thus, the implementation of this sub-project, consisting in the construction of the substation and related TL, will lead to a change in the electricity supply in the area, which will have a positive impact on the whole development complex of the industry and the well-being of the population.

A summary of potential environmental and social risks and impacts with mitigation measures during sub-project implementation is presented in Table 8 below.

Table 8. Summary table of impacts

Impact	
Impacts and Mitigation Measures - Construction Phase	
Air quality	Moderate impact
Landscape	Moderate impact
Land acquisition	Moderate impact
Soil, erosion and slope stability	Moderate impact
Water Quality	Minor impact
Flora and fauna	Minor impact
Noise and vibration	Moderate impact
Impacts on access and movement	Minor impact
Impacts on cultural resources	Minor impact
Health and safety of workers	Moderate impact
Health and safety of community	Moderate impact
Electric current impact	Minor impact
Magnetic field impact	Minor impact
Traffic and Safety	Moderate impact
Labor camp tensions risk with nearby communities	Moderate impact
Impacts and mitigation measures- Operation phase	
Air quality	Minor impact
Water Quality	Minor impact
Flora and fauna	Minor impact
Noise	Minor impact
Security forces	Minor impact

5. Organizational Requirements

The following section presents an overview of the environmental and social management activities to be undertaken as part of the overall project implementation. Roles and responsibilities of various organizations in carrying out these activities, identification and strengthening of organizational capacity required to achieve the mandatory goals and objectives of the project.

At this stage, an environmental and social monitoring program has been prepared and preliminary costs associated with its implementation identified.

5.1. Organizational structure and division of responsibilities

The overall organizational structure of environmental management for the project is shown in Figure 5.




Figure 5: Organizational Structure of the Environmental Protection Authority

5.2. National Electric Grid of Uzbekistan (NEGU)

The NEGU has overall responsibility for the preparation, implementation and financing of environmental and social management and monitoring tasks related to the project. The NEGU carries out its functions through the PIU, which will be responsible for the overall project implementation and will be tasked with the day-to-day management of the project as well as monitoring.

The staff appointed by the PIU (environment specialist-1 and social specialist -1) will take over all tasks relevant to the environmental and social assessment. The Project Implementation Unit (PIU) working with and on behalf of NEGU will be responsible for the implementation of the proposed monitoring plan. Implementation of the mitigation measures presented in the ESMP and monitoring plan during construction will be the responsibility of

the Contractor. A representative of the PIU and the environmental and social specialists of the supervision consultants will supervise the monitoring of the implementation of the mitigation and monitoring measures during construction. EPC contractor's environmental and social specialists will work with international specialists (Construction Supervision Consultants) to address complex issues that may arise and will provide ongoing updates in the form of reports to be submitted to the PIU. The PIU staff will also be supported by the Supervision Consultants. The Consultant team will be required to provide an Environmental Impact Monitoring Specialist and a Social Impact Monitoring Specialist.

The feasibility study and detailed design have been consulted with the Goskomekologiya, the DEIS has been prepared and submitted for review, and the sub-project is being considered for approval. Ongoing engagement with Goskomekologiya will be required during sub-project implementation.

Makhalla Committees and Khokimiyats (local authorities) and NGOs will assist in organising meetings, also to provide information on affected communities, environmental and social impacts. A report on the stakeholder engagement process will form an integral part of the internal monitoring report prepared by the PIU.

The implementation of mitigation measures during the construction phase will be the responsibility of the Contractor in accordance with the sub-project specifications and contractual requirements. The environmental specialists and social specialist of the Supervision Consultant will monitor the implementation of the mitigation measures during the construction stage.

Screening and assessment of environmental and social impacts indicates that the main environmental and social issues arising during construction are not significant and are reversible and can be significantly reduced by implementing the recommended mitigation measures listed in the ESMP (Table 9). Monitoring and compliance with measures during construction is therefore very important.

Construction environmental monitoring has a supervisory function, the main purpose of which is to ensure compliance with the ESMP. Certain actions in the ESMP that are to be verified are included in the Monitoring Plan (see Table 11). These include the preparation of plans for all aspects of the work, such as workplace safety plan, waste management plan etc., which must be completed and approved prior to construction. Air control, noise control and water quality parameters should also be included.

The PIU should monitor sub-project development, implementation of the Environmental and Social Management Plan (ESMP), environmental and social monitoring results and report to the WB in a timely manner. The proposed form is included as Annex 2.

5.3. Reporting requirements

During sub-project implementation, the Supervision Consultants, in cooperation with the PIU, will need to:

- (i) develop an environmental audit protocol for use during construction, and develop a detailed monitoring and management plan; and
- (ii) conduct regular environmental and social monitoring and submit quarterly reports based on the data obtained during monitoring and laboratory analyses.
- (iii) implement the GM and create a database of complaints received and resolved.

The PIU will provide the following documents on environmental and social reporting to the WB:

- (i) **Baseline monitoring report.** The report should be submitted to the WB prior to

construction work and includes a detailed environmental management and monitoring plan (including data collection locations, parameters and frequency of collection), baseline environmental data, relevant standards and allocation of data collection responsibilities.

- (ii) **Environmental and social monitoring reports (monthly, quarterly and annual).** Reports will include environmental mitigation measures, actions taken to control, data collected, results of analyses, recommended mitigation measures, environmental training data, and identified environmental and social violations. The report will include the implementation of the ESMP, which will present: (i) the organizational structure prior to resolution of environmental issues and issues of the Contractor and the Supervision Consultant, (ii) data on obtaining all necessary permits related to environmental issues during construction works; (iii) description of environmental and social impacts during the reporting period and mitigation measures implemented during this period; (iv) any previously unidentified impacts that occurred during the reporting period and measures implemented; (v) any construction related accident, e.g., and (VI) any complaints about the environmental and social aspects of affected people or other parties, the number of nature of grievances received and resolved.

6. Environmental and Social Impact Mitigation Plan

The Environmental and Social Management Plan (ESMP) has been developed and submitted (see Table 9) and should be updated during detailed design. NEGU should ensure and monitor that contractors prepare an ESMP for the site where construction works will be carried out, based on this ESMP and the actual situation in the sub-project area.

Sub-project-related environmental impacts have been described in detail previously in the relevant sections of this ESMP. The mitigation measures required to address the impacts identified in the ESMP have been summarized in each of the relevant sections covering the physical, biological and socio-economic environment affected by the sub-project. The identified impacts and specific mitigation measures have been consolidated into an Environmental and Social Management Plan (ESMP) shown in Table 9, which includes timelines, responsibilities and, where appropriate, cost estimates for each measure.

During construction, mitigation measures will be aimed at ensuring that contractors carry out all works in accordance with environmental regulations. Proper waste management, use of fuels and lubricants, revegetation of any areas cleared during construction, water use management, and control of construction dust levels will be required.

The NEGU shall ensure the following:

(i) the contractor's obligation to undertake environmental mitigation measures as defined in the ESMP, all necessary measures to be included in the tender documents and later in the contract documents; (ii) the cost of recommended environmental and social mitigation measures to be specified as a separate item in the construction budget. This allocation of a separate budget for environmental mitigation measures is essential to ensure their implementation. (iii) obligation of the contractor to appoint staff responsible for implementing environmental mitigation measures during construction and reporting to the PIU. (iv) obligation of the contractor to prepare a Site Environmental and Social Action Plan (SESAP) for implementation of the ESMP, identifying individual areas where mitigation measures are to be implemented. This SESAP can be submitted as part of the Site Environmental Action Plan (SESAP) and the Occupational Health and Environmental Protection Plan that are part of the contractor's contractual obligations. In addition, all plans for waste disposal, tree planting, water use should also be prepared for approval by the supervision consultant on behalf of the PIU and (v), the contractor, in collaboration with the PIU, will be responsible for addressing any complaints and grievances in relation to construction activities.

Table 9. Environmental and Social Management Plan

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
A. Construction of the Substation "Koltsevaya" 500 and related TL	Environment					
Major construction and installation of new equipment	1. Water resources					
	1.1. Pollution of water (surface or ground), soil by construction waste	Compliance with repair and construction standards and regulations; - Waste storage only in designated places	EPC Contractor	Current technical control and supervision of construction works	Included in EPC costs	RPIU, PIU, local construction supervision agency, local nature protection authorities

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
	1.2. Pollution of water from the construction site	<ul style="list-style-type: none"> - All fuel and chemical storage facilities (if any) should be placed on an airtight base with internal bunding; - Disposal of lubricating oils and other potentially hazardous liquids into the ground or into water bodies is prohibited; - Sedimentation tanks or reservoirs - Spill Response Equipment - Immediate cleaning in the event of a spill of fuels and lubricants and disposal of their residues; - Ensuring removal of surface and drainage runoff from the work site; - Timely cleaning of working sites from construction waste; - Conducting restoration works in the disturbed areas. - Fuel and lubricant tanks must be filled according to the prescribed norms; - Do not allow waste petroleum products to be discharged onto the terrain, follow refuelling and transport regulations 	EPC Contractor	Periodically, during construction works. Measurement at wastewater discharge site of petroleum products, suspended solids: Once per quarter for 1 year	Included in EPC costs 5,0\$ EPC Contractor	RPIU, PIU, local construction supervision agency, GosSIAK, Uzhydromet, or other accredited laboratory
	2. Land resources 2.1 Excavation works	Restrict the use of heavy machinery to avoid land subsidence and compaction .	EPC Contractor	Current technical control and supervision of construction works	Included in EPC costs	RPIU, PIU, local construction supervision agency.

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
		<p>During trench excavation soil is stockpiled along the route of water and sewer pipes after pipe-laying</p> <p>Backfilling of trenches with soil compaction</p> <p>Revegetation of disturbed soil cover (ShNK 2.05.02 - 07; KMK 2.05.03-97 2);</p> <p>Prior to the start of main construction works, the fertile soil layer is removed and moved to the site for temporary storage.</p> <p>The construction area is cleared of debris and landscaped upon completion of construction activities.</p>				
	2.2. Soil contamination with construction waste	<ul style="list-style-type: none"> Organization of timely collection of construction wastes, their transportation and storage in the designated places 	EPC Contractor	Periodically, during construction work	Included in EPC costs	RPIU, PIU, local construction supervision agency.
	2.3. Fuel and oil leakages	<ul style="list-style-type: none"> Lubricant containers must be filled according to the regulations; - Do not allow used oil products to be drained onto the terrain; - Comply with refuelling and transportation regulations. 	EPC Contractor working technicians	Routine monitoring during construction work	Included in EPC costs	RPIU, PIU, local construction supervision agency, local bodies of SES and nature protection authorities

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
	2.4. Breakthrough of water and sewer pipes and flooding of adjacent lands	Urgent work on pipeline rehabilitation and land remediation.	EPC Contractor	Periodically, during construction work	Included in EPC costs	RPIU, PIU, local construction supervision agency, local bodies of SES and nature protection authorities
	3. Atmospheric air					
	3.1 Dust from building overhaul, dismantling of equipment, from excavation work during building construction and transportation	<ul style="list-style-type: none"> - Dust suppression during the construction period - Washing of roads, construction sites and appropriate cover for transport of waste - When asbestos is detected, personnel must wear protective masks and use all ACM regulations; - Watering of structures to be dismantled during the dismantling process - Demolition work must stop if wind speed exceeds 20 km/h - Do not burn debris and other materials - Cover the loose material body with a tarpaulin during transportation. 	Contractor	Periodically, during construction work Dust measurements once per quarter for 1 year (unscheduled inspections)	Included in EPC costs EPC Contractor 5,0\$	RPIU, PIU, local construction supervision agency, local bodies of SES and nature protection authorities

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
	3.2.Pollution from exhaust fumes from running machinery and vehicles	<ul style="list-style-type: none"> - The use of construction vehicles and vehicles that meet national or international standards; - Prohibition of parking of vehicles with a running engine; - Avoidance of excessive numbers of vehicles on the premises and smoke emitting vehicles. 	EPC Contractor Traffic inspection	Routine monitoring during construction works Measurements of soot, carbon monoxide once per quarter for 1 year (unscheduled inspections)	Included in EPC costs EPC Contractor 6,0\$	RPIU, PIU, local construction supervision agency, local bodies of SES and nature protection authorities

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
	3.3. Noise, vibration from working machines	<ul style="list-style-type: none"> - No work at the weekend near home or town; - Provision of Noise Protection Kits (PPE) to workers; - Minimize reverse movement of vehicles. - Combustion engines with silencers - Pneumatic tools with silencer - Restrictions on the operation of machinery at night. - Limitation of work time to daytime; (SanPin RUz № 0267-09 3; SanPin № 0120-01 4). - Provision of construction workers with safety instructions (ShNK 3.06.03 - 08; KMK 3.06.04-97) - Noise levels in nearby residential areas should not exceed 55 dB during the day and 45 dB at night. For workers, the noise level in the workplace should not exceed 70 dB. (SanPiN RUz № 0267-093; SanPiN № 0120-014); - Locate sources of noise and vibration as far away from buildings as possible; - Noise-suppression devices - Fence off the work area for public safety; - Inform the population about temporary restrictions related to the repair and construction works. 	EPC Contractor	Routine monitoring during construction works Noise measurements 2 times a year	Included in EPC costs 6,0\$ EPC Contractor	RPIU, PIU, local construction supervision agency, local bodies of SES and nature protection authorities

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
	3.4. Open burning of waste	- No incineration of waste or other materials will be carried out on the construction site.	EPC Contractor	Routine monitoring during construction works	Included in EPC costs	RPIU, PIU, local construction supervision agency, local bodies of SES and nature protection authorities
	4. Household waste	<ul style="list-style-type: none"> - Provide waste containers at each workstation in designated waste storage areas; - Define a waste management with recycling; - Storage of waste in closed containers; - Prohibit the use of damaged containers. Regularly check the integrity of the container; - Timely removal to landfill; - Training / education 	EPC Contractor	Constantly	Included in EPC costs	RPIU, PIU, local construction supervision agency, Inspector for Waste Management Control under the Department for Ecology and Environmental Protection of Tashkent region

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
	5. Construction waste	<ul style="list-style-type: none"> - Identification of different types of construction waste: toxic, hazardous, inert, - Marking the containers to quickly determine what kind of waste they contain; - Recycling of waste with further processing ; - Identification of waste storage sites; - Use of soil inert waste during road levelling and repair, etc; - Weekly records should be kept of the types and volumes of waste removed from the site; - Training / education 	EPC Contractor	Constantly during construction	Included in EPC costs	RPIU, PIU, local construction supervision agency, Inspector for Waste Management Control under the Department for Ecology and Environmental Protection of Tashkent region

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
	6. Hazardous waste	<ul style="list-style-type: none"> - Short on-site storage of hazardous waste, timely disposal or transfer for recycling to specialized organizations that need to be contracted - Training / education - Personal protective equipment Comply with the rules of storage of tanks with fuel and lubricants in sealed packaging <ul style="list-style-type: none"> - Waste disposal should be carried out by a licensed waste management company. Asbestos-containing waste should be placed in polyethylene or non-woven bags and further removed in special sealed containers marked "asbestos".	EPC Contractor	Constantly	Included in EPC costs	RPIU, PIU, local construction supervision agency, Inspector for Waste Management Control under the Department for Ecology and Environmental Protection of Tashkent region
	7. Flora					
	Damage of trees and vegetation cover	<ul style="list-style-type: none"> - Restoration of damaged vegetation; - Construction of temporary roads without damage to shrubbery and woody vegetation; - Installation of water and sewerage networks to be carried out avoiding damage to vegetation. 	EPC Contractor	After completion of the work	Included in EPC costs	RPIU, PIU, local construction supervision agency, Inspectorate for Biodiversity Control under the Department for Ecology and Environmental Protection of Tashkent region
	8. Fauna					

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
	Impacts on fauna	- Limiting work at night; -Cutting trees, if necessary, outside the bird nesting period. -Protect fish by protecting surface watercourses from pollution.	EPC Contractor	Periodically	Included in EPC costs	RPIU, PIU, local construction supervision agency, Inspectorate for Biodiversity Control under the Department for Ecology and Environmental Protection of Tashkent region
	9. Physical cultural heritage					
	Chance finds of cultural value	- Termination of work, notification of interested organizations, extraction of finds according to the established rules . - execution of construction works at a distance of at least 100 m from archaeological remains after prior permission.	EPC Contractor	Constantly, as it is extracted	Included in EPC costs	RPIU, PIU , Regional Inspection for Protection of Cultural Heritage Objects
	10. Socio-economic aspects					

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
	10.1. Safe and healthy working conditions, elimination of accidents and incidents	<p>Supervision of the health of workers shall include: (a) medical examinations prior to appointment;</p> <ul style="list-style-type: none"> - To prevent infection and to slow transmission of COVID-19, do the following: <ul style="list-style-type: none"> Wash your hands regularly with soap and water, or clean them with alcohol-based hand rub. Maintain at least 1 meter distance between you and people coughing or sneezing. Avoid touching your face. Cover your mouth and nose when coughing or sneezing. Stay home if you feel unwell. Refrain from smoking and other activities that weaken the lungs. Practice physical distancing by avoiding unnecessary travel and staying away from large groups of people. (b) periodic medical examinations; monitoring the quality parameters of drinking water; - Observance of safety procedures; - Familiarization of employees with hazardous materials (such as asbestos materials, fuel and lubricants, etc.); - Turn off installations that are not in use; - Use machinery and equipment as intended. - Personal protective equipment; 	EPC Contractor	Constantly	Included in EPC costs	RPIU, PIU, local construction supervision agency

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
		<p>-Compliance with regulations and instructions to ensure electrical and fire safety.</p> <p>-In order to reduce the exposure of personnel to electric fields, it is necessary during construction:</p> <p>a) use outdoor switchgear metal structures made of galvanized, aluminized or aluminum elements;</p> <p>b) ladders to climb the metal gantry cross-bars should be placed inside the metal gantry posts (the ladders placed outside should be fenced with shielding devices, ensuring permissible levels of electric field strength inside).</p> <p>B) Outdoor switchgear bus arrangement must be rigid, made of aluminium alloys.</p>				

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
	10.2. Traffic accidents on public roads	<ul style="list-style-type: none"> -Regular maintenance and control of vehicles - Alarm, lighting, safety signs, barriers and signalers; - Information campaigns to improve safety - Emergency action plan 	EPC Contractor traffic police	Routine monitoring during construction works	Included in EPC costs	RPIU, PIU, traffic officer
	10.3. Blocked access	<ul style="list-style-type: none"> - Provision of an alternative road to bypass the construction site, if available - Organize operations in such a way that access to residences, income-generating assets and public facilities is not blocked 	EPC Contractor	Routine monitoring during construction works	Included in EPC costs	RPIU, PIU, traffic officer

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
	10.4 Unequal opportunities for vulnerable groups of workers	-Promote fair treatment, non-discrimination and equal opportunities for workers. For large-scale construction - Ensure that a Contractor's LMP is drawn up and implemented. -Develop a code of conduct to be followed by the workforce in relation to the worksite and surrounding community. -Worker behavior and community awareness on GBV -Create a GBV-sensitive grievance mechanism -Prohibit forced labor, target local workers where possible	EPC Contractor	Routine monitoring during construction works	Included in EPC costs	RPIU, PIU
B. Operation and maintenance	Environment					
New substation and related TL	Pollution of soil and water, untreated sewage, used transformer oil.	- Strictly regulated waste collection and disposal to designated locations. - Ensure that surface and drainage runoff is diverted away from the work site; - Timely cleaning of work areas from construction waste.	Local staff, Regional branch of NEGU	Regularly, according to a set schedule	NEGU	MEN, Tashkent Regional Committee for Ecology and Environment Protection, SES

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
	Atmospheric air pollution	<ul style="list-style-type: none"> - No burning of rubbish or other materials will take place at the substation - No parking of vehicles with the engine running; - Avoiding excessive amounts of vehicles in the area and vehicles emitting smoke. 	Local staff, Regional branch of NEGU	Regularly, according to a set schedule	NEGU	MEN, Tashkent Regional Committee for Ecology and Environment Protection, SES
	Household and industrial waste	<ul style="list-style-type: none"> - Provision of sites for temporary storage of waste; - Timely removal to landfill or recycling; - Water supply in case of fire; -Automatic fire extinguishing system automatic fire extinguishing system; - Composting of sweepings from cleaning operations; -Control the storage of fuel and oil containers in a sealed container. 	Local staff, Regional branch of NEGU	Regularly, according to a set schedule	NEGU	MEN, Tashkent Regional Committee for Ecology and Environment Protection, SES

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
	-	<ul style="list-style-type: none"> • Develop environmental and other criteria regulating maximum permissible environmental loads in a timely manner; - Observe treated wastewater discharge regimes and established quality standards, and protect water bodies from pollution and fouling; - Discharge of municipal, drainage and other wastewater with the permission of the nature protection authorities in accordance with the established procedure; - Introduce waste-free and low-waste technologies, reduce generation of industrial and household waste, decontaminate, recycle it, follow the rules for its sorting, storage, disposal and recycling. 	Local staff, Regional branch of NEGU	Quarterly monitoring of treated wastewater discharges. Periodic monitoring by nature protection authorities for compliance with wastewater discharge conditions	5 \$ NEGU	<p>MEN, Tashkent Regional Committee for Ecology and Environment Protection, SES</p> <p>Water Inspector under the Department for Ecology and Environmental Protection of Tashkent region</p>
	Vegetation	<ul style="list-style-type: none"> - Greening of the area around the substation; -Restoration of trees in case of felling; -Organisation of irrigation and control of vegetation condition. 	Local staff, Regional branch of NEGU	Constantly		<p>NEGU, MEN Inspectorate for Biodiversity Control under the Department for Ecology and Environmental Protection of Tashkent region</p>

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
	Emergency situations	<ul style="list-style-type: none"> - Ambulance base. - To ensure the safety of the installation and maintenance work on the substation, provision is made for: <ul style="list-style-type: none"> - Fencing of live parts; - Required isolation distances between live parts and individual connections; - Pedestrian and vehicular traffic; - Electromagnetic and mechanical interlocks to exclude erroneous actions of personnel during operational switching operations; - Protective earthing device; - Remote control of 110 kV circuit breakers, main - 10 kV circuit breakers; - System for control and automation of operating modes; - Short-circuit and overvoltage protection: - Working and emergency lighting. - Compliance with regulations and instructions to ensure electrical and fire safety. -In order to reduce the exposure of personnel to electric fields, it is necessary during construction: <ul style="list-style-type: none"> - ladders to climb the metal gantry cross-bars should be placed inside the metal gantry posts (the ladders placed outside should be fenced with shielding devices, ensuring permissible levels of electric field strength inside). - Safety awareness campaigns - Emergency Action Plan. 	Local staff, Regional branch of NEGU	Constantly during operation		Local staff, NEGU, MEN

Stage	Problem	Mitigation measures	Responsible organizations	Monitoring activities	Cost, thousand \$	Responsible bodies for monitoring the implementation of the work (in order of participation)
	Socio-economic aspects					
	Occupational health and safety	<ul style="list-style-type: none"> - To develop a comprehensive health and safety improvement program for service personnel; - Introduction of an effective system for monitoring the health of the population; - Installation of an automated security system; - Worker health supervision should include (a) pre-employment medical examinations; (b) periodic medical examinations; Compliance with safety regulations; - familiarizing employees with the procedure of working with hazardous materials (such as asbestos materials, fuel and lubricants, etc.). - Personal protective equipment; - Safety equipment; - Constant training. 	Local staff, Regional branch of NEGU	Periodic control		NEGU, MEN, SES.
	Threats to the health of staff	Operation of transformer equipment in compliance with established standards.	Local staff, Regional branch of NEGU	Monthly control		NEGU, Local staff, MEN

7. Environmental and Social Monitoring Plan

Environmental and social monitoring is a very important aspect in environmental management, both during the construction and operation phases. The Environmental Monitoring Plan (EMoP) deals with substation and TL construction in general, installation of equipment, major construction, public interaction and safety assurance. Important parameters of the monitoring program are air, noise and surface water quality in the sub-project area.

In response to the environmental impacts identified during the surveys, an Environmental Monitoring Plan has been developed and is presented in Table 11. The contract documents will contain a list of all necessary mitigation measures and a time frame for monitoring the implementation of these measures. Part of the monitoring will be the supervision of the design activities in order to control the compliance of the Contractor's actions with the contract during construction.

The Construction Supervision Consultant, in cooperation with the PIU during sub-project implementation, shall:

- Develop an environmental audit protocol for the construction phase and develop a detailed monitoring and management plan;
- Regularly supervise environmental and social monitoring and submit quarterly reports: the main parameters to be monitored are set out in Table 11, and
- Regularly monitor the sub-project activities, and submit quarterly reports based on monitoring data and laboratory analyses. The main parameters to be monitored are set out in Table 11. The Contractor and the Construction Supervision Consultant will be responsible for collecting the environmental monitoring data for the appointed organization (e.g. Goskomekologiya).

The following measures will be taken to ensure compliance with the environmental monitoring program during sub-project implementation:

The tender and contract documents will clearly set out the Contractor's obligations for the environmental measures presented in Table 9 and will be added to the contract specification;

The costs of the recommended environmental and social mitigation measures should be included as an element in the Bill of Quantities (BoQ). This will ensure that there is a specific budget line item for environmental mitigation. At the time of procurement, the Contractor will be requested to include these costs in its tariffs and to present the mitigation costs as a separate line item in the BoQ.

The PIU will employ an environmental and social supervising consultant who will be responsible for the implementation of the Contractor's environmental and social, safety and health responsibilities. The consultant will cooperate with the local administration.

7.1. Estimates for proposed environmental protection measures

The environmental costs of the sub-project should be included in the sub-project cost and include the following: (i) costs of financing studies, consultations, and disclosures for the updated ESMP (ii) costs of implementing mitigation measures, including tree planting, and (iii) costs of financing environmental monitoring and reporting. The table below summarizes the costs required to mitigate environmental and sociological measures and monitoring.

Table 10: Costs of environmental protection for mitigation and monitoring

Baseline Monitoring

Activity / Item	Frequency	Location & number of samples or selections.	Cost per unit	Cost
Air quality	once a quarter	2 at the substation, 2 near the nearest settlements - Total sample = estimated 4	100\$ US	400 \$ US
Water Quality	once a quarter	At least 2 water samples in the nearest canal at the wastewater discharge site = 2 - Total sample estimated 2	50 \$ US	100 \$ US
Soil contamination	once a quarter	At least 2 places in the sub-project area = 2 samples	75 \$ US	150\$ US
Noise	once a quarter	Road starting point, completion point and vulnerabilities as determined by the PTN. Total number - estimated 5	40 \$ US	200\$ US
Total for the quarter				650 \$ US

Proposed environmental and social monitoring programs.

Parameter	Monitoring parameters	Location	Measurements (incl. Methods and equipment)	Frequency of measurement	Responsibilities (Including Review and Reporting)	Cost
Air quality	NOX TSP CO Dust	In sub-project areas, access roads	Day monitoring, at least 4 measurements	Monthly for dust, other parameters once a quarter	Environmental specialist submits a report to the PIU	3000 \$
Noise	Noise	In sub-project areas, access roads	Day monitoring, at least 4 measurements	Monthly	Environmental specialist submits a report to the PIU	3000 \$
Water Quality	Petroleum products, suspended solids	Nearest canal at wastewater discharge site	Portable Devices	Quarterly	Environmental specialist submits a report to the PIU	3000 \$
Socio-economic parameters	Complaints received on GM	Communities related to the sub-project area	Number of complaints submitted and number resolved.	Monthly	RPIU	No direct costs
Total						9,000 \$

BOD = biochemical oxygen demand, CO = carbon oxide, NOx = nitrogen oxides, pH = expression of basic or acidic state, TSP = total suspended solids.

Institutional strengthening and training

Strengthening of institutional activities	Position(s) (institutions, contractors, supervision consultants)	Schedule	Cost estimates
Mitigation	EPC Contractors, sub-project engineers, NEGU, PIU/RPIU	10 days	10,000 \$
Monitoring	State Committee on Ecology, sub-project engineers, members of the municipality	5 days	5,000 \$
Environmental and social assessment (principles, methodology)	State Committee for Ecology, NEGU, PIU/RPIU	10 days	10,000 \$
TOTAL			25,000 \$

Table 11. Environmental and Social Monitoring Plan

Problem	Mitigation measure	Efficiency Indicator	Means of checking	Frequency	Responsible authority/individual	Costs (US \$)
PRE-CONSTRUCTION PHASE						
Soil contamination.	Remove, preserve and reuse the topsoil according to the most applicable practice; the soil should be preserved in such a way as to prevent erosion or loss of fertility; Ensure that spills of oil products and other substances cannot occur and, if they occur, immediate action is taken to minimize the impact on the soil. Storage of construction materials properly in designated areas.	Substation area sub-project	Check the preliminary design	Once or more depending on the revision of the sub-project	PIU, NEGU	No data
Public Access	Access is provided to the local population, including pedestrians, non-motorized vehicles, livestock	Access not hindered/ Provision of alternatives	Check the preliminary design and maps	Once or more depending on the revision of the sub-project	PIU, NEGU	No data
Infrastructure	Avoid impacts on existing/planned infrastructure.	Infrastructure is not affected	Check the preliminary design and maps	Once	PIU, NEGU	No data
Embankments/ constructions	Design embankments, crossings, culverts, etc.	Embankments, etc., meet the requirements	Check the preliminary design and maps	Once	PIU, NEGU	No data

Problem	Mitigation measure	Efficiency Indicator	Means of checking	Frequency	Responsible authority/individual	Costs (US \$)
Noise barriers	Noise protection is revised during design	Noise protection enabled where it is rational/effective	Check the preliminary design and maps	Once	PIU, NEGU	No data
Sources of materials and transportation	Ban the extraction of materials and/or violation of protected areas. The bidder must identify the sources of materials, specify transportation methods, provide a real breakdown of costs, including the ongoing maintenance and rehabilitation of access roads, dirt roads.	Requirement of contract. The Bidder provides information.	Check	Once or more depending on the result	PIU, NEGU	No data
Pollution control on the highway	Application of pollution control measures	The measures are included in the sub-project.	Check	Once or more depending on the result	PIU Environmental specialist	No data
Access to information/public relations	Inform the population about construction progress. Successful implementation of the complaints mechanism. Complaints are accepted and dealt with quickly.	Information materials must be produced. A complaint mechanism is prescribed. Complaints officers and complaints committees have been identified. Complaint logs exist and are updated.	Sample checks, feedback from the local population / NGOs, feedback from the engineer	Approximately once a month during the entire construction period, most often with complaints from the public	Environmental and social specialist, reports to PIU	Included in the budget of the consultant on technical supervision
CONSTRUCTION STAGE						
Minimization of inconvenience to the local population	No noisy work near settlements between 20:00 and 6:00 and on public holidays. Maximum noise level at site	Minimal complaints	Sample checks, feedback from the local population / NGOs, feedback	Approximately once a month during the entire construction period, most	Environmental specialist reporting to the PIU	Provision must be foreseen by the contractor

Problem	Mitigation measure	Efficiency Indicator	Means of checking	Frequency	Responsible authority/individual	Costs (US \$)
	<p>boundary 70 dB(A). Construction machinery/equipment are equipped with noise and exhaust gas protection. Access for local people, including pedestrians, non-motorised vehicles and livestock is ensured. Rubbish and waste is removed from construction campsites/areas by contractor. Waste is removed from construction towns/areas by the contractor. The Contractor shall adequately protect all buildings, structures, works, services or facilities from damage, disturbance or deterioration during the duration of the contract and in case of damages, ensure timely and adequate repair, and compensation in case losses have been caused</p>		from the engineer.	often with complaints from the public		
Health and safety	<p>Availability of drinking water, toilets, showers and canteens. Training on health and HIV/AIDS, and GBV; COVID19, Code of Conduct Ambulance equipment and training. Personal protective equipment and training.</p>	Everything described has been provided, training has been conducted.	Sample checks, training documents, accident protocols, feedback with the engineer and workers.	Approximately once a month during the entire construction period, most often with complaints from the public	Environmental specialist reporting to the PIU	Included in the budget of the consultant on technical supervision

Problem	Mitigation measure	Efficiency Indicator	Means of checking	Frequency	Responsible authority/individual	Costs (US \$)
	Training of safety on construction and emergency response. Accidents registration logs. Public safety measures.					
Site Clearance	When clearing vegetation, keep as many trees and vegetation as possible.	No damaged trees / felled without permits.	Sample checks, feedback from the engineer and workers	Approximately once a month during the clearing of the site	Environmental specialist reporting to the PIU	See above
Infrastructure	Damage to infrastructure	No damage found	Sample checks, feedback from the engineer	Approximately once a month during construction	Environmental specialist reporting to the PIU	See above
Drainage control	Site Drainage Plan Settling ponds Standing water	A drainage plan for the site exists and is being implemented. There are no silted/muddy discharges of water outside the site into water bodies. No oil film on bodies of water near the site. No standing water on/off site.	Sample checks, local community / NGO feedback, engineer feedback.	Approximately once a month during construction	Environmental specialist reporting to the PIU	See above
Control of fuel and chemical pollution	The rules about leak prevention. Regulations on fuel storage, transport and washing of the vehicle. Prohibition on washing the vehicle, in rivers/wetlands. Storage of lubricants and chemicals in wetlands is not	All rules have been developed and approved. No untreated work-related spills of lubricant/bitumen/cement/concrete on site. Regulations on fuel storage, transport and washing of the vehicle	Sample checks, local community / NGO feedback, engineer feedback.	Approximately once a month throughout the construction period, most often in the case of complaints from the population	Environmental specialist reporting to the PIU Π	See above

Problem	Mitigation measure	Efficiency Indicator	Means of checking	Frequency	Responsible authority/individual	Costs (US \$)
	permitted and, if unavoidable, must be stored in specially constructed, embankment protected areas.	exist and are enforced. Workers are aware of the ban Vehicles are not washed in rivers/wetlands. Any unavoidable storage of oils and chemicals in wetlands will be organized in specially constructed, embankment protected areas.				
Waste Management	Garbage and waste in/from work camps and territories is cleaned up by the contractor. Storage of waste in wetland areas is not permitted.	Waste management plan exists and is being implemented Garbage and waste are disposed of Wastes are not stored in wetlands The disposal sites should be visited and monitored periodically.	Sample checks, local community / NGO feedback, engineer feedback.	Approximately once a month throughout the construction period, most often in the case of complaints from the population	Environmental specialist reporting to the PIU	See above
Household waste	Household waste from construction camps and the canteen will be collected by a licensed organization. All construction waste must be removed from the site and special managed landfills must be established under the supervision of local authorities. Workers' waste should be removed from the site on a regular basis. On completion of the contract, all temporary structures should be removed from the site.	There is no local impact unless there is accommodation near existing settlements. Construction camps are being cleared.	Sample checks, Feedback from workers and the engineer	Regular monthly monitoring of the site and waste collection and disposal activities by Technical Supervision Consultants	Technical Supervision Consultant and nature protection authorities	

Problem	Mitigation measure	Efficiency Indicator	Means of checking	Frequency	Responsible authority/individual	Costs (US \$)
Management of Hazardous Materials, Fuels and Lubricants	Hazardous waste (or chemical waste) will be properly stored, treated and disposed of. Hazardous waste will be stored in designed locations where warning signs will be posted. A maximum load limit for trucks carrying hazardous wastes should be developed.	Rivers and sub-project areas are being cleaned.	Sample checks, Feedback from workers and the engineer	Monthly monitoring of the site and waste collection and disposal activities by Technical Supervision Consultants	Technical Supervision Consultant and nature protection authorities	
Wastes to be recycled	Materials to be recycled, such as wooden trench boards, steel, timber, fasteners, packaging materials, etc., will be collected and sorted from other waste sources on site. The collected materials to be recycled will be reused for other sub-projects or transferred to waste treatment plants for recycling.	The sub-project corridor is being cleared.	Sample checks, Feedback from workers and the engineer	Regular monthly monitoring of the site and waste collection and disposal activities by Technical Supervision Consultants	Technical Supervision Consultant and nature protection authorities	
Construction waste water	Mitigation measures will be included in construction contracts to prevent spills and leakages of construction materials (e.g. bitumen, petroleum products, chemicals, fly ash, cement, sand and aggregates) during transport. Stocks of construction materials such as bitumen, petroleum products and chemicals must be properly covered or placed under a	The sub-project corridor is being cleared.	Sample checks, Feedback from workers and the engineer	Regular monthly monitoring of the site and waste collection and disposal activities by Technical Supervision Consultants	Technical Supervision Consultant and nature protection authorities	

Problem	Mitigation measure	Efficiency Indicator	Means of checking	Frequency	Responsible authority/individual	Costs (US \$)
	shelter to prevent contamination from rainfall.					
Local road network management	Dirt roads Prior to construction, the actual condition of all dirt roads should be assessed and photographed (possibly by PIU in cooperation with the Engineer). The requirement to restore all temporarily used dirt roads to their original condition.	Dirt roads are photographed Roads are pre-stressed where necessary. Damage is being repaired. Roads are restored to their original state after use.	Sample checks, local community/NGO feedback, engineer feedback	Approximately once a month throughout the construction period, most often in the case of complaints from the population	Environmental specialist reporting to the PIU	See above
Road safety		A traffic management plan exists and is being executed. No increase in traffic accidents. No unnecessary traffic disturbance.	Sample checks, local community/NGO feedback, engineer feedback	Approximately once a month throughout the construction period, most often in the case of complaints from the population	Environmental specialist reporting to the PIU	See above
Noise Control	No noisy work in the vicinity of settlements between 20:00-06:00 and on public holidays Maximum noise level at the boundary of the site is 70 dB(A).	A noise control plan exists and is being implemented. There are no too noisy equipment / vehicles on the site. Workers working on noisy equipment/working on noisy vehicles use appropriate PPE.	Sample checks, local community/NGO feedback, engineer feedback	Approximately once a month during the entire construction period - including nighttime and holidays, most often with complaints from the public	Environmental specialist reporting to the PIU	See above

Problem	Mitigation measure	Efficiency Indicator	Means of checking	Frequency	Responsible authority/individual	Costs (US \$)
Air Pollution Control	Air Pollution Control	Workers who work with equipment / perform work that is polluting the air use appropriate PPE.	Sample checks, local community/NGO feedback, engineer feedback	Regular inspections of subcontractor sites asphalt plant, quarries, etc.). Approximately once a month throughout the construction period, more often with complaints from the population.	Environmental specialist reporting to the PIU	See above
Air Quality Baseline Survey.	Baseline air quality monitoring should be conducted immediately after the date of acceptance of the application, to the extent practicable, to determine air pollutant levels at specified monitoring sites. Proposed locations require the approval of an environmental specialist.	Complaints received through the GM.		The results of the monitoring should be presented within two (2) working days after the completion of the monitoring. Appropriate actions shall be taken upon the results of the monitoring. The final results shall be presented in the required initial environmental baseline report.	Environmental specialist should be responsible for the daily problems of managing environmental measures. The contractor should not start work on the site until the Environmental specialist has started work on the site.	Tracking and reporting costs should be part of the contractor's proposal

Problem	Mitigation measure	Efficiency Indicator	Means of checking	Frequency	Responsible authority/individual	Costs (US \$)
Dust control	Dust control Dirt roads in residential areas need to be watered/cleaned to reduce dust. Dust-producing materials should be covered during transport.	Dust control plan exists and is being implemented. No dust on dirt roads in residential areas. No dust from construction machinery transporting materials.	Sample checks, local community/NGO feedback, engineer feedback	Approximately once a month throughout the construction period, most often in the case of complaints from the population	Environmental specialist reporting to the PIU	See above
Cultural heritage/archeological finds	Plan for cultural/archeological finds	A plan for cultural/archeological finds exists and is being implemented, workers are familiar with the plan.	Sample checks	Once	Environmental specialist reporting to the PIU	See above
Greening	Felled trees must be replaced by planted trees.	Tree planting and care	Sample checks	Once, at the end of construction	Environmental specialist reporting to the PIU	See above
POST-CONSTRUCTION/OPERATION PHASE						
Impacts on biodiversity	Successfully implemented sub-project measures to minimize impacts on biodiversity.	Minimum change in original biodiversity	Reports on biodiversity monitoring in after-construction and operational phase	Monitoring once a year (summer) for five years after the route is put into operation.	MEN/ local NGOs with WB assistance	Included in the annual PIU's operation and maintenance budget
Traffic management	Compliance with speed modes and proper signage setting Training and sensitization of the local population. Any additional pedestrian crossings should be investigated	In places of access to construction near populated areas	Post-construction and operational monitoring reports	Regular reporting of any accidents and complaints	Road maintenance company	Included in the annual PIU's operation and maintenance budget

Problem	Mitigation measure	Efficiency Indicator	Means of checking	Frequency	Responsible authority/individual	Costs (US \$)
Environmental Monitoring	<ul style="list-style-type: none"> - Plan of accidental spills - Implementation of measures to minimize the risks of ground and surface water pollution. - Speed Monitoring of Vehicles. - Noise monitoring program. - Air quality monitoring program. - Water quality monitoring program. - Waste management monitoring program: <ul style="list-style-type: none"> -regular waste disposal, - Traffic accident log -Registration of complaints from the public (appointment of a community liaison officer). 		Post-construction and operational monitoring reports	Regular reporting (monthly / annually)	PIU	Included in the annual PIU's operation and maintenance budget

8. Public Consultations and Information Disclosure

8.1. General information

This section describes the disclosure, consultation and participation that took place as part of the ESMP process, as well as the results of these activities and what should be planned throughout the duration of the Project. More information about stakeholder engagement process is presented in project SEP which serves as a framework document for the site-specific consultations also.

The section consists of the following paragraphs:

- Methodology/tools used to inform and involve the public in the environmental and social assessment process.
- Discussion of issues raised by different stakeholders.
- Responses to stakeholders on how the project could address their concerns raised during the consultation process.
- Documentation of the public consultation, including dates, names, topics and summary of discussions, and results.
- Identification of measures for continued consultation during the implementation of the environmental management program.

8.2. Principles of consultation

Early and on-going consultation, disclosure and involvement of key stakeholders is a basic requirement for WB-funded projects.

The specific objectives of public disclosure and consultation are:

- Ensuring that all legal and international financial requirements related to consultation have been met;
- Inclusion of all stakeholders in project planning, to improve project plan, implementation and monitoring;
- Encouraging an open dialogue with the local community, and especially with project affected persons in the locations where the project is located;
- Ensuring that appropriate project information on environmental and social risks and impacts is disclosed to stakeholders in a timely, understandable, accessible and appropriate manner and format.
- Keep all interested and affected parties informed of project progress; and
- Providing a Grievance Mechanism to receive and address complaints.

Public consultation is based on the principles that public involvement should be free from outside influence, interference, coercion and intimidation, Public consultation should be carried out with timely, relevant, understandable and accessible information.

Consultations should always be well planned and based on the principles of respectful and meaningful dialogue.

8.3. Stakeholder engagement activities

General principles

Stakeholder engagement will be carried out according to the SEP throughout the project development period to identify and incorporate the views of stakeholders and those who

may be affected by the project throughout its life cycle, and to ensure open and transparent two-way communication between the project proponent and stakeholders. The approach to engagement is designed to meet both national and international requirements.

The following general principles will guide stakeholder engagement activities:

- Content of the public consultation documents will have accessible and adequate information about the Project and will not raise excessive concerns (regarding potential negative impacts) or expectations (regarding potential positive impacts such as job creation, etc.);
- Written information will be accompanied by visual illustrations and explanations necessary to understand the project;
- Information will be disclosed in the local language(s), where relevant, and in a manner that is accessible and culturally appropriate, taking into account any vulnerable groups; incl. women;
- Any issues raised will be explained and answered;
- If key issues of particular concern arise, workshops may be offered to explain technical processes, assessment methods and quality assurance measures to verify results and ensure compliance with mitigation procedures; and
- Efforts will be made to explain not only the proposed draft and process of the ESMP, but also the applicable national laws and regulations, international principles and standards and how compliance will be addressed. The proposed sub-project and the ESMP have been developed on the basis of national laws and regulations, international principles and standards.

8.4. Stakeholder Engagement

The main issues raised by participants during the initial meetings and consultations in April 2021, Tashkent region, covered the following topics:

- Whether houses and land will be affected during construction,
- Impacts on the natural environment and population during construction work
- Social and economic benefits of the project
- Whether a stable electricity supply will be available after the project implementation
- Whether trees will be felled during construction work.

In the opinion of the population, in order to ensure a comprehensive approach to solving electricity supply problems, the main areas that need to be focused on at present are, firstly, the improvement, repair and replacement of existing substation equipment, as it is obsolete; secondly, the repair and construction of power transmission lines. Thus, the current Project is fully consistent with the expectations and needs of the Tashkent region population.

8.5. Grievance Mechanism (GM)

For the project, open and transparent communication between the Receiver and its stakeholders is an essential element of good international practice. Effective stakeholder engagement can enhance the social and environmental sustainability of a project, improve its perception and contribute substantially to its successful development and implementation.

Project-related grievance procedures serve to provide an effective and systematic mechanism for responding to questions, providing feedback and addressing complaints from those affected by project activities.

The timely resolution of grievances and complaints in a satisfactory manner is an important project implementation process. The project's Grievance Mechanism will seek to resolve

grievances and complaints and engage with all stakeholders.

Anyone who has experienced an impact or has concerns about project activities can use the GM and get answers to questions that have arisen.

In Uzbekistan, the mechanism for consideration of citizens' appeals and complaints (GM) is widely used in accordance with the Law of the Republic of Uzbekistan №ZRU-378 dated 03.12.2014 "On appeals of legal entities and individuals". Interested parties can apply via the Internet to the portal <https://my.gov.uz/ru>. Also, since 2017, "People's Reception Offices" have been functioning, where citizens can address their concerns.

The project site shall have a log book to record citizen appeals and actions to resolve the issue raised.

A Grievance Mechanism (GM) will be established to receive and ensure resolution of grievances and complaints from local residents and stakeholder organizations on social and environmental issues. The GM will consist of two levels, as outlined below.

Table 12. Grievance redresses mechanism and its levels

Level/steps	Process
<p>Level 1-</p> <p>Site engineer of NEGU, the working office of Contractor, makhalla committee, and district khokimiyats</p>	<p>The aggrieved person applies directly to local Makhalla committee or working office of Contractor or Site Engineer of NEGU¹. PIU regional representative will be in charge of collecting/receiving and registration complaints from makhalla committee, Contractor offices, site engineer(s) and from khokimiyat on a weekly base.</p> <p>The alternative entry point for complaints will also be khokimiyats due to their obligations defined by national legislation; After registration of received complaints, the PIU regional representative will review the nature/specificity of the complaint and will forward it to the relevant party for resolving. In parallel, the PIU regional representative will inform the PIU in Tashkent about the received complaint and further actions undertaken for its resolution. Depending on the nature of a complaint, it may go to the Contractor, Land Cadaster bodies, Makhalla committees, district branches of Nature Protection Committee or newly created "Centralized Fund for the Compensation of Losses of people and legal entities after land acquisition for the needs of the state and society." At this level, the complaint should be resolved in two weeks.</p>
<p>Level 2 –</p> <p>PIU in Tashkent and a Grievance Redressal Committee headed by the PIU/NEGU</p>	<p>In case the grievance was not redressed at the first stage or the applicant is not satisfied with the decision made/solution, s/he can submit the grievance directly to the PIU secretariat in Tashkent. By established procedure, the secretariat of the PIU will review the complaint and will forward complaints to the respective department to a made decision on its redress. In case the grievance is not related directly to the project, any further instance will be recommended to the applicant where s/he should apply for the decision making.</p> <p>If the complaint requires more time and resources for resolution, the PIU may establish a Grievance Redressal Committee with following</p>

¹ During the consultations on GM issues the representatives of NENU ensured that it is the common practice for the organization to have a supervising engineer in each construction site.

Level/steps	Process
	members such as representatives from secretariat PIU and NEGU high-level management staff, district Khokimiyat, cadastral and Nature protect departments etc. All complaints will be resolved in 15 days, and in case additional details are required, a maximum of 30 days will be used to resolve and close the complaint with prior notification of complainant.

If the issue was not solved or the applicant is dissatisfied with the decision/resolution, an aggrieved person at any stage of the GM process may submit the grievance to Economic Court (Court of Law) where a decision will be made by relevant national legislation.

Complaints may be made at any time during the preparation and implementation of the project. However, the project grievance mechanism does not prevent affected persons from contacting the national/state legal system to resolve their grievances at any stage of the GM process. Submitting a complaint, comments and/or suggestions is free of charge.

The Contractor shall include information on grievances in the monthly progress reports submitted to the PIU, which in turn will include summarised information in the semi-annual social monitoring reports (SASMRs).

Communication

Prior to commencing work at the site, the Contractor shall:

- Notify GM to the public in the project impact area.
- Establish and publish a 24/7 grievance hotline.
- Ensure that names and contact numbers of representatives, PIU, Regional branch of NEGU and Contractor are posted on notice boards outside the construction site.

The grievance redress process has been formally introduced during the public consultation. The Grievance Mechanism will also be presented during routine community meetings in the Project area during the construction stage.

Annexes

Annex 1. Minutes of the Public Consultation

Public Consultation took place on April 7, 2021. Representatives of different organizations involved in the project participated in the meeting. Among them were representatives of regions' khokimiyats, of regions Goskomecology. The main purpose of that meeting was to introduce participants with information on planning activities in project sites including construction of a new SS Koltcevaya with OHTL and Tashkent and to explain the main statement of WB's safeguards policies, including ESMF, ESMP, RF, LMP, SEP.

Place/format: NEGU Office in Tashkent in video conference format.

Date: 7 April 2021

Electricity Sector Transformation and Resilient Transmission (ESTART) Project

Public hearing: Disclosure and public discussions on the Social Environmental Principles (SEPs)

Prepared by: "Ekostandart" Environmental and Social Specialists: Olga Vakhidova-Mordovina and Zilola Kazakova

Presented by: Zilola Kazakova

Target audience: Target audience: Representatives of regional and local authorities involved in environmental and social activities of the project were invited (specialists of the Department of Land Resources and State Cadastre, Committee for Ecology and Environmental Protection, Ministry of Energy of RUz, representatives of the Khokimiyat, etc.). The list of participants is attached. NEGU specialists and residents of the directly affected settlements (substations, TLs, access roads) were also invited.

The oral presentation was made in the local language (Uzbek).

The following topics were discussed:

Description of the project and its components; potential project planning activities, national environmental, social legislation and relevant WB requirements: identified social and environmental impacts and mitigation measures; developed social and environmental safeguards documents (ESMF, ESMP, RF, LMR and SEP) and the need to develop an ESMP for each sub-project, in the context of previously developed documents; Grievance Mechanism and project contact information for affected people and organizations; further stages of project implementation.

After the discussion, the Consultant shared with the participants a presentation and provided contact numbers of project representatives where participants of the public consultations can contact the Consultant or a representative of the PIU in case of any questions and necessary clarifications.

The participants were then given the opportunity to express their opinions and ask questions. The consultants took turns addressing the representatives of each project region. Representatives of the NEGU regional branches reported that the information presented on the project is clear and understandable and that they had already received information on the technical and project data during the initial consultations during the field visit.

Participants discussed the following topics and questions:

#	Topic / Question	Answers/Discussions
1	Is it necessary to have a complaints and suggestions log at each project site?	Each regional NEGU branch should keep a register of complaints and appeals. The issue of complaint logging is very important in the implementation of project activities.
2	Placement of project socio-environmental documents, access to project information	All developed project documents have been posted on the NEGU and World Bank website, a detailed presentation and brochure was sent to each project region for further distribution to residents and other PAPs.

After the discussions, the project consultants asked female participants to also participate in consultations on gender equality and GBV as part of project activities and events.

Place/format: NEGU Office in Tashkent in video conference format.

Date: 7 April 2021

"Electricity Sector Transformation and Resilient Transmission" Project (ESTART)

Public consultation: On Gender Equality and Gender-Based Violence in the Context of Project Activities

Prepared by: Ekostandart Ekspert Environmental and Social Specialists: Olga Vakhidova-Mordovina and Zilola Kazakova

Presented by: Zilola Kazakova

Target audience: NEGU Women specialists and women residents of the directly affected communities (substations, transmission lines, access roads) were invited to attend the consultations. The consultations were attended by 28 women, with the following composition - 10 female employees of the regional MEN and 18 female residents of the project area.

The oral presentation was made in the local language (Uzbek).

The following topics were discussed:

Issues of gender equality and gender-based violence in the context of this project and women's lives in today's society, the frequency of individual consultations with women employees of the NEGU and residents in the project areas, training on gender topics for NEGU staff and regional units, the need to establish a gender focal point at regional level, reviewing recruitment and promotion policies, ensuring comfortable and safe working conditions for women, with sufficient latrine facilities with a sufficient number of restrooms and showers, assistance in the opening of the women's association and its integration into the trade union organization of the NEGU.

The consultants also reported that the Project will contribute to reducing gender bias in the energy sector by including specialized knowledge and capacity building services that do not limit women to certain gender roles and social expectations. The project will include monitoring these actions. As part of the project, the NEGU will develop an action plan on

GBV, the activities of which will also be integrated into the contractors' ESMP. Project training and capacity building activities will include specific GBV-focused modules so that all project staff and key stakeholders have a better understanding of GBV risks and required mitigation measures within the project.

After the discussion, the Consultant provided the contact numbers of the project representatives where participants in the public consultations can contact the consultant or the PIU representative in case of any questions and necessary clarifications.

The participants were then given the opportunity to express their opinions and ask questions. The consultants took turns addressing the representatives of each project region.

Participants discussed the following topics and questions:

#	Topic / Question	Answers/Discussions
1	On the side of the Syrdarya Regional Branch, staff raised the issue of the need to improve sanitary and hygienic conditions in the workplace for women.	The Consultant noted that the project was to consider providing a comfortable and safe working environment for women, with sufficient latrines and showers, and that the appeal would be passed on to the NEGU management.
2	Participants have some concerns about the confidentiality of the information discussed during these consultations.	The consultants advised that there is no need to be afraid to express their opinions to female employees of NEGU enterprises, local female residents, that the environment and conditions of these consultations provide for free expression of their complaints, concerns and possible risks related to the project implementation. Women will be treated with strict confidentiality and separate complaints mechanisms will be implemented.
3	What kind of training will be provided on these issues?	The NEGU will develop an action plan on GBV, the activities of which will include training among women employees of the NEGU, women of project areas, employees of contractors.

The participants reported that gender-based violence is a very topical issue in everyday life, but that mentality and traditions do not allow for an open discussion, but they are grateful for the opportunity to speak out.

THE WORLD BANK
IBRD - IDA | WORLD BANK GROUP

Сана: 07.04.2021 йил
Худуд: Ўзбекистон МЭТ АЖ Андижон МЭТ филиали
Лойиҳа номи: "Ўзбекистон МЭТ АЖнинг №01-04-28/63 сонли Фаскограммасига асосан

Жаҳон банки иштирокида "Магистрал электр тармоқлари потстанцияларини замонавийлаштириш ва реконструкция қилиш" инвестиция лойиҳасини амалга ошириш чора тадбирлари тўғрисидаги қарорига асосан видео конференциясида катташуучилар рўйхати

№	ФИО	Лавозими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1.	Алибеков Фарходбек	Бон муҳандис	Андижон МЭТ филиали	99-607-51-81	
2.	Мирсаидов Нумонжон	МКБ бошлиғи	Андижон МЭТ филиали	99-437-04-13	
3.	Хантова Дилфуза	ПСХ муҳандиси	Андижон МЭТ филиали	99-087-55-51	
4.	Умурзаков Рустамжон	Юрист	Андижон МЭТ филиали	99-994-10-04	
5.	Мадумаров Мадамминбек	Эламентёр	Андижон МЭТ филиали	97-235-07-15	
6.	Иудашева Барнохон	Техник	Андижон МЭТ филиали	97-992-04-45	
7.	Юсупова Шахзода	Истисодчи	Андижон МЭТ филиали	99-086-20-33	
8.	Мухтарова Наргиза	ХВ муҳандиси	Андижон МЭТ филиали	98-780-05-23	

eco standart

THE WORLD BANK
IBRD - IDA | WORLD BANK GROUP

9.	Мамадиева Нигорахон	Алоқа замонтер муҳандис	Андижон МЭТ филиали	93-445-20-93	
10.	Аскарон Ошанжон	Алоқа замонтери	Андижон МЭТ филиали	99-085-22-02	
11.	Солтбек Султонжон	Алоқа замонтери	Андижон МЭТ филиали	91-610-22-25	
12.	Тўйчибеков Раҳматулло	П/С Юстир 220 кВ бошлиғи	Андижон МЭТ филиали	99-439-48-70	
13.	Матқосимов Муҳаммадошжим	П/С Фозиладон-220 кВ бошлиғи	Андижон МЭТ филиали	99-607-20-38	
14.	Азизов Бахтиёржон	П/С Хасан-220 кВ бошлиғи	Андижон МЭТ филиали	99-010-01-97	
15.	Хамдамов Латифжон	Муҳандис	Андижон МЭТ филиали	99-580-19-78	

КўК расми: *[Signature]* Д.Хантова

eco standart

THE WORLD BANK
IBRD - IDA | WORLD BANK GROUP

Сана: 2021 йил 7 апрел
Худуд: Бухоро МЭТ филиали
Лойиҳа номи: «Электр тармоғини узаттириш ва барқарор узатиш (ESTART)

№	ФИО	Лавозими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1.	Мирзаев Самат Саидович	бон муҳандис	Бухоро МЭТ филиали	93-459-80-88	
2.	Алқом Эрон Абдуллаев	Бон муҳандис урунбосари	Бухоро МЭТ филиали	91-485-57-43	
3.	Жураев Тоғиб Ташаратович	Капитал қурилиш бўлими бошлиғи	Бухоро МЭТ филиали	97-384-19-00	
4.	Султонов Давлат Хужайрадович	Бон кассоби	Бухоро МЭТ филиали	93-967-55-00	
5.	Розиева Гулшан Ҳудайалиевна	Ходимаки бўлими муҳандиси	Бухоро МЭТ филиали	91-402-58-69	
6.	Жонова Насиба Яхшиевна	Рока истисод гуруҳи етказиш тармоғини	Бухоро МЭТ филиали	91-445-76-92	
7.	Ибрагимов Закиржон	Капитал қурилиш бўлими	Бухоро МЭТ филиали	91-449-42-32	

eco standart

THE WORLD BANK
IBRD - IDA | WORLD BANK GROUP

8.	Рашидов Бекмурат Аминович	Капитал қурилиш бўлими етказиш муҳандиси	Бухоро МЭТ филиали	93-626-07-48	
9.	Холимов Ирода Ориповна	Хавфсизлик ва махфус ишлар гуруҳи муҳандиси	Бухоро МЭТ филиали	91-447-80-57	
10.	Муршова Гули Шахидиловна	Резерв хизмати ва Электроник хизмати техникаси	Бухоро МЭТ филиали	90-718-67-56	
11.	Хайдаров Жақол Раҳимович	Ишлаб чиқариш техника гуруҳи етказиш муҳандиси	Бухоро МЭТ филиали	97-301-27-00	
12.	Файзуллаев Надиржон Собир угли	Моддий техника таъминоти гуруҳи муҳандиси	Бухоро МЭТ филиали	91-407-00-43	
13.	Рузиев Шарифжон Исомович	Моддий техника таъминоти гуруҳи амбор муаввизи	Бухоро МЭТ филиали	93-479-39-07	
14.	Асқарон Сардор Журакулович	Алоқа хизмати бошлиғи	Бухоро МЭТ филиали	93-452-27-26	

Директор филиали Вух МЭС: *[Signature]* С.Сарсанов

eco standart

THE WORLD BANK
IBRD - IDA | WORLD BANK GROUP

Сана: 07.04.2021
Худуд: "Ўзбекистон Илмий Электр Тармоғини" АЖ Андижон
Лойиҳа номи: "Ўзбекистон Илмий Электр Тармоғини" АЖ Андижон филиалининг электр тармоғини қайта қуриш ва барқарор узатиш (ESTART) лойиҳасига асосан

№	ФИО	Лавозими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1.	Қасимов Б.М.	директор	Андижон МЭТ	91-60-80-88	
2.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
3.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
4.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
5.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	

eco standart

THE WORLD BANK
IBRD - IDA | WORLD BANK GROUP

Сана: 07.04.2021
Худуд: Самарқанд вилояти Чирчиқ тумани 200 кВ
Лойиҳа номи: "Самарқанд вилояти Чирчиқ тумани 200 кВ электр тармоғини қайта қуриш ва барқарор узатиш (ESTART) лойиҳасига асосан"

№	ФИО	Лавозими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
2.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
3.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
4.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
5.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
6.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
7.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
8.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
9.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
10.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
11.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	

eco standart

THE WORLD BANK
IBRD - IDA | WORLD BANK GROUP

Сана: 07.04.2021
Худуд: "А.О. АЭС Ўзбекистон" филиал, Самарқанд вилояти
Лойиҳа номи: "А.О. АЭС Ўзбекистон" филиал, Самарқанд вилояти

№	ФИО	Лавозими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
2.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
3.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
4.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
5.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
6.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
7.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
8.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
9.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
10.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
11.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	

eco standart

THE WORLD BANK
IBRD - IDA | WORLD BANK GROUP

Сана: 07.04.2021
Худуд: Самарқанд вилояти Чирчиқ тумани 200 кВ
Лойиҳа номи: "Самарқанд вилояти Чирчиқ тумани 200 кВ электр тармоғини қайта қуриш ва барқарор узатиш (ESTART) лойиҳасига асосан"

№	ФИО	Лавозими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
2.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
3.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
4.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
5.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
6.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
7.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
8.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
9.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
10.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	
11.	Қасимов Ш.С.	бон муҳандиси	Андижон МЭТ	97-235-07-15	

eco standart

Сана: 07.04.2021 йил
Худуд: Хоразм вилояти

Лойиҳа номи: «Магистрал тармоқлардаги подстанцияларни модернизация ва реконструкция қилиш» (фаза II) - «Хазрат» ПС

№	ФИО	Лавазими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1	Исмаилов Абдукарим	Бун муҳим қисми	Исмаилов Худуд Косимов	92-708-02-01	
2	Чинаев Умар	БҲО м.и	Оталик Исмаилов	99-352-14-03	
3	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
4	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
5	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
6	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
7	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
8	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
9	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
10	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	

Сана: 07.04.2021 йил
Худуд: Хоразм вилояти

Лойиҳа номи: «Магистрал тармоқлардаги подстанцияларни модернизация ва реконструкция қилиш» (фаза II) - «Хазрат» ПС

№	ФИО	Лавазими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
11	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
12	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
13	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
14	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
15	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
16	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
17	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
18	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
19	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
20	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
21	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
22	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
23	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
24	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
25	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
26	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
27	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	

Сана: 07.04.2021 йил
Худуд: Тошкент вилояти

Лойиҳа номи: «Магистрал электр тармоқларини модернизация ва реконструкция қилиш» (II фаза) ПС "Тракторс"

№	ФИО	Лавазими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
2	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
3	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
4	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
5	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
6	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
7	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
8	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
9	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
10	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
11	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	

Сана: 7.04.2021 й.
Худуд: Тошкент шаҳар Магистрал Электр Тармоқлари филиали

Лойиҳа номи: «Магистрал электр тармоқларини модернизация ва реконструкция қилиш» (II фаза) ПС "Тракторс"

№	ФИО	Лавазими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
2	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
3	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
4	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
5	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
6	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
7	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
8	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
9	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
10	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
11	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	

Сана: 7.04.2021 йил
Худуд: Қашқадар вилояти

Лойиҳа номи: «Магистрал электр тармоқларини модернизация ва реконструкция қилиш» (II фаза) ПС "Тракторс"

№	ФИО	Лавазими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
2	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
3	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
4	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
5	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
6	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
7	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
8	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
9	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
10	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
11	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
12	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
13	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	

Сана: 2021 йил 7 апрел
Худуд: Бухоро МЭТ филиали

Лойиҳа номи: Электр тармоқини узарттириш ва барқарор узатиш (ESTART)

№	ФИО	Лавазими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
2	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
3	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	
4	Ҳасанов Фарҳод	БҲО м.и	Оталик Исмаилов	99-352-57-53	

List of women-participants of public consultation

Сана: 07.04.2021 йил
Худуд: "Ўзбекистон МЭТ" АЖ Андижон МЭТ филиали

Лойиҳа номи: "Ўзбекистон МЭТ" АЖнинг №01-04-28/63 сонли Факограммасига асосан

Жаҳон банки интироқида "Магистрал электр тармоқлари потстанцияларини замонавийлаштириш ва реконструкция қилиш" инвестиция лойиҳасини амалга ошириш чора тадбирлари тўғрисидаги қарорига асосан видео конференциясида катташуричилар рўйхати

№	ФИО	Лавазими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1	Хайтова Дилфуза	ПСХ муҳандиси	Андижон МЭТ филиали	99-087-55-51	
2	Илутпанова Баринхон	Телевик	Андижон МЭТ филиали	97-992-04-45	
3	Юсупова Шахноза	Иктисодчи	Андижон МЭТ филиали	99-086-20-33	
4	Мухтарова Наргиза	ХБ муҳандиси	Андижон МЭТ филиали	98-780-05-23	
5	Мамадинова Нигорхон	Алоқа элмонтер	Андижон МЭТ филиали	93-445-20-93	

КУК ранси: Хайтова Д.Хайтова

Сана: 2021 йил 7 апрел
Худуд: Бухоро МЭТ филиали

Лойиҳа номи: Электр тармоқини узарттириш ва барқарор узатиш (ESTART)

№	ФИО	Лавазими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1	Рузиева Гулзийон Тўймуродова	Ходимлар бўлими муҳандиси	Бухоро МЭТ филиали	91-402-58-09	
2	Хокиева Насиба Яхшиева	Режа иктисодчиси	Бухоро МЭТ филиали	91-445-76-92	
3	Хокиева Ирода Оринова	Хавфсизлик ва манусилар тўғрисида муҳандиси	Бухоро МЭТ филиали	91-447-80-57	
4	Муминова Гули Шамсидинова	Режа хизмати ва Электросинов хизмати техник	Бухоро МЭТ филиали	90-718-67-56	

Директор филиали Бух МЭТ: С.С.Арсланов



Сана: 07.04.2021
 Худуд: Ўзбекистон Илмий Электр Тармоқлари» АЖ давлати Наманган
Электр тармоқлари филиали давлат йилдаги Ўзбекистон
 Лойиҳа номи: «Тендер тегилик таъдирси бўйсун олмасин ишга қўйиладиган бўлган»

№	ФИО	Лавозими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1.	Алимова Ашшога	Тендер бўлими муди	Илмий НЭТ	91-340-14-31	
2.	Попилова Иброҳим	Ўзбекистон Илмий Электр Тармоқлари филиали	Илмий НЭТ	91-344-18-31	
3.					
4.					
5.					
6.					
7.					
8.					
9.					
10.					
11.					



Сана: 07.04.2021
 Худуд: Ўзбекистон Илмий Электр Тармоқлари» АЖ давлати Наманган

Лойиҳа номи: «Электр тармоқлари бўйсун олмасин ишга қўйиладиган бўлган»

№	ФИО	Лавозими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1.	Алимова Ашшога	Тендер бўлими муди	Илмий НЭТ	91-340-14-31	
2.	Попилова Иброҳим	Ўзбекистон Илмий Электр Тармоқлари филиали	Илмий НЭТ	91-344-18-31	
3.	Алимова Ашшога	Тендер бўлими муди	Илмий НЭТ	91-340-14-31	
4.	Попилова Иброҳим	Ўзбекистон Илмий Электр Тармоқлари филиали	Илмий НЭТ	91-344-18-31	
5.					
6.					
7.					
8.					
9.					
10.					
11.					



THE WORLD BANK
IBRD • IDA | WORLD BANK GROUP

Сана: 07.04.2021
 Худуд: Ўзбекистон Илмий Электр Тармоқлари» АЖ давлати Наманган

Лойиҳа номи: «Электр тармоқлари бўйсун олмасин ишга қўйиладиган бўлган»

№	ФИО	Лавозими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1.	Алимова Ашшога	Тендер бўлими муди	Илмий НЭТ	91-340-14-31	
2.	Попилова Иброҳим	Ўзбекистон Илмий Электр Тармоқлари филиали	Илмий НЭТ	91-344-18-31	
3.	Алимова Ашшога	Тендер бўлими муди	Илмий НЭТ	91-340-14-31	
4.	Попилова Иброҳим	Ўзбекистон Илмий Электр Тармоқлари филиали	Илмий НЭТ	91-344-18-31	
5.					
6.					
7.					
8.					
9.					
10.					
11.					



THE WORLD BANK
IBRD • IDA | WORLD BANK GROUP


Сана: 07.04.2021
 Худуд: Ўзбекистон Илмий Электр Тармоқлари» АЖ давлати Наманган

Лойиҳа номи: «Электр тармоқлари бўйсун олмасин ишга қўйиладиган бўлган»



№	ФИО	Лавозими	Ташкилот номи	Контакт маълумотлари (e-mail)	Имзо
1.	Алимова Ашшога	Тендер бўлими муди	Илмий НЭТ	91-340-14-31	
2.	Попилова Иброҳим	Ўзбекистон Илмий Электр Тармоқлари филиали	Илмий НЭТ	91-344-18-31	
3.	Алимова Ашшога	Тендер бўлими муди	Илмий НЭТ	91-340-14-31	
4.	Попилова Иброҳим	Ўзбекистон Илмий Электр Тармоқлари филиали	Илмий НЭТ	91-344-18-31	
5.					
6.					
7.					
8.					
9.					
10.					
11.					





Олий мажлиси раиси



Photos of public consultation







Women public consultation





Annex 2. Proposed forms for monitoring implementation

Environmental Monitoring

№ Contract	Water		Noise		Air		Soil	Garbage
	Drinking	Waste	Nearest populated area	Active work area	Nearest populated area	Active work area	Active work area	Active work area
1								
12	PC	C	N					
12A								



C - Conforms



PC - Partly conforms



N - Not conform

Status of implementation of environmental measures

№ Contract	Noise control plan	Work sites	Camp	Waste Disposal Plan	Health and Safety Management Department	Road Traffic Management Plan	Dust Control Plan	Accidental Spill Plan
1	PC	C	C	N				
12								
12A								



C - Conforms



PC - Partly conforms



N - Not conform

Annex 3. Asbestos Containing Material Management Plan (Example)

Applicability

The Asbestos Containing Material Management Plan (ACMMP) applies to all project construction or reconstruction sites and any related areas. Contractors employed by Project are legally responsible for their construction sites and related areas and must follow the provisions of the Project ACMMP within those locations. Specifically, this procedure must be used to ensure the safe handling, removal and disposal of any and all Asbestos Containing Materials (ACM) from those areas.

Immediate Action

On discovering ACM on a Project site, the contractor must:

- a) Stop all work within a 5 m radius of the ACM and evacuate all personnel from this area;
- b) Delimit the 5 m radius with secure fencing posts, warning tape and easily visible signs warning of the presence of asbestos;
- c) If the site is in an inhabited area, place a security guard at the edge of the site with instructions to keep the general public away;
- d) Notify the Safeguard Specialist and arrange an immediate site inspection.

Equipment

To remove asbestos from a construction site, contractors must provide the following equipment:

- a) Warning tape, sturdy fence posts and warning notices;
- b) Shovels;
- c) Water supply and hose, fitted with a garden-type spray attachment;
- d) Bucket of water and rags;
- e) Sacks of clear, strong polythene that can be tied to close;
- f) Asbestos waste containers (empty, clean, sealable metal drums, clearly labelled as containing asbestos).

Personal Protective Equipment (PPE)

- a) All personnel involved in handling ACM must wear the following equipment, provided by the contractor:
- b) Disposable overalls fitted with a hood;
- c) Boots without laces;
- d) New, strong rubber gloves;
- e) A respirator is not normally required if there are only a few pieces of ACM in a small area, and if the ACM is damp;
- f) There must be no smoking, eating or drinking on a site containing ACM.

Decontamination Procedure 1: Removing small pieces of ACM

- a) Identify the location of all visible ACM and spray each lightly but thoroughly with water;
- b) Once the ACM is damp, pick up all visible ACM with shovels and place in a clear

- plastic bag;
- c) If ACM debris is partially buried in soil, remove it from the soil using a shovel and place it in the plastic bag;
 - d) Insert a large label inside each plastic bag stating clearly that the contents contain asbestos and are dangerous to human health and must not be handled;
 - e) tie the plastic bags securely and place them into labelled asbestos waste containers (clean metal drums) and seal each drum;
 - f) Soil that contained ACM debris must not be used for backfill and must instead be shovelled by hand into asbestos waste containers;
 - g) At the end of the operation, clean all shovels and any other equipment with wet rags and place the rags into plastic disposal bags inside asbestos waste containers.

Decontamination Procedure 2: Removing ACM-contaminated backfill

- a) a) If soil containing ACM debris has inadvertently been used for backfill this must be sprayed lightly with water and to be removed manually with a shovel as much as possible and placed directly into asbestos waste containers (i.e. not stored temporarily beside the trench);
- b) Any ACM during the taking out by shovel must be placed in a clear plastic bag;
- c) After the trench has been re-excavated to 300 mm, if no visible ACM remains, the trench can be refilled with imported clean topsoil using an excavator.

Disposal

ACM should be disposed of safely at a local hazardous-waste disposal site if available, or at the city municipal dumpsite after making prior arrangement for safe storage with the site operator.

- The Contractor must arrange for the disposal site operator to collect the sealed asbestos waste containers as soon as possible and store them undisturbed at the disposal site.
- At the end of construction Contractors must arrange for the disposal site operator to bury all ACM containers in a separate, suitably-sized pit, covered with a layer of clay that is at least 250 mm deep.

a) Personal Decontamination

At the end of each day, all personnel involved in handling ACM must comply with the following decontamination procedure:

- At the end of the decontamination operation, clean the boots thoroughly with damp rags;
- Peel off the disposable overalls and plastic gloves so that they are inside-out and place them in a plastic sack with the rags used to clean the boots;
- If a disposable respirator has been used, place that in the plastic sack, seal the sack and place it in an asbestos waste container;
- All personnel should wash thoroughly before leaving the site, and the washing area must be cleaned with damp rags afterwards, which are placed in plastic sacks as above.

b) Clearance and Checking-Off

- The decontamination exercise must be supervised by site supervisors (engineering or environmental).
- After successful completion of the decontamination and disposal, the Contractor should visually inspect the area and sign-off the operation if the site has been cleaned satisfactorily.
- The contractor should send a copy of the completion notice to the PIU, with photographs of the operation in progress and the site on completion.

TRAINING

RPIU's Environmental Specialist may hire the specialized companies to conduct training on ACCMP implementation for Contractors staff and RPCU and PIU. The training will include a session focusing on ACM, which covered:

- a. Risks of contact with ACM;
- b. Responsibilities for dealing with ACM on project's construction sites;
- c. The Project's ACMMP and the Protocol for site clean-up;
- d. Awareness-raising for the contractors' workforce.

COST ESTIMATE

Costs incurred by contractors in implementing the ACMMP are included in their budget in ESMP budget.